



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 09, 2022 **Inspection Result:** **FAILED**

Permit Number: B-21-0583

Property Address: 507 31ST AVE SW, PUYALLUP, WA 98373;

Contractor: SUPERIOR BUILDERS INC PO BOX 1849 FIFE, WA 98354-1849 PERFECT CLIMATE INC 4426 221ST PL NE REDMOND, WA 98053 (425) 260-6955

To construct: TI COMBINE (2) SUITES INTO 1 OFFICE ~ STEWART TITLE

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; complete install of expansion tank.
2 ; provide Dbl. check at hard lined coffee maker as required on last plumbing final inspection dated 4/28/2022.
1:provide dbl check at coffee per last 2 insp
2:plumbing vents to be 10ft away or 2 ft above intakes on roof
- 2 1 ; provide back flow certification test report prior to plumbing final.

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org