



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 16, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: PRUSR20220749

Property Address: 925 S MERIDIAN, PUYALLUP, WA 98371;

Contractor: MR ROOTER PLUMBING 2000 S 116TH ST SEATTLE, WA 98168

To construct: Spot repair of sewer line from outside front door of business to inside front door

On this day we have inspected your construction for **Engineering Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Contractor installed 6"pvc inspection tee out near the tie in connection. Okay to backfill. Need to install proper cap w/ adaptor and cover. Will final when concrete has been poured back.

Corrections:

Sincerely,

Jason Little
Engineering Tech IV
JLittle@PuyallupWA.gov



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 435-3636