



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** May 16, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCTI20220309

**Property Address:** 333 S Meridian Unit 105, Puyallup WA 98371

**Contractor:** BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060

**To construct:** Enclose door opening, install 2 new doors with accompanying small wall portions, cap off old plumbing fixtures. Box in some electrical outlets and perform electrical work to install a small amount of lighting. Ray Cockerham has reached us to be the reviewer. on this small T.I job.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** t.c.o. approved for 10 working days from 5//16/2022

**Corrections:**

1 1 ; complete access doors at mop sink and hotwater heater electrical j-box.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684