



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 31, 2022

Inspection Result: **FAILED**

Permit Number: E-20-0612

Property Address: 3213 WILDWOOD PARK DR, PUYALLUP, WA 98374;

Contractor: PEASE & SONS PO BOX 44100 TACOMA, WA 98444 Brandon Haskins
10601 Waller Rd E Tacoma, WA 98446 (253) 370-6559

To construct: CIVILS ~ FERRUCCI JHS REMODEL & ADDITION

2021 STORM SDC FEES UPDATED

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: the construction entrance is full of dirt. the entrance must be rebuilt per standard (1' deep with filter fabric then 4"-8" rock) All catch basins in the site not surrounded by asphalt or concrete must be encircled by silt fence. the straw waddles along the bus path are broken down and need to be replaced.

Corrections:

- 1 rebuild construction entrance per city standard
- 2 encircle all catch basins with silt fence that are not in paved areas
- 3 replace straw waddles along the bus loop

Sincerely,

Jeff Hill
Engineering Tech IV
Jhill@PuyallupWA.gov
(253) 841-5424