



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 07, 2022

Inspection Result: NOT READY

Permit Number: PRCTI20220017

Property Address: 4227 S MERIDIAN, Unit: C, PUYALLUP, WA 98373;

Contractor: TOP DRAWER DEVELOPMENT 25252 SW MCCONNELL RD SHERWOOD,
OR 97140

To construct: Remodel of an Existing Tenant Space: ADDRESS: 2200 N. MERIDIAN
Wall Partitions, Suspended Ceiling, Security Gate

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide electrical cover approval prior to ceiling grid inspection.
 - 2 ; complete all mechanical rough-in prior to ceiling grid inspection.
- not ready

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org