

Linda Lian

From: Linda Lian
Sent: Thursday, April 7, 2022 2:44 PM
To: Brian Johnson
Subject: RE: PRSMS20210109

The applicant was required to reapply for a permit. The new permit number is PRSMS20220789

Thank you Brian

Linda Lian
Engineer Technician IV
253-841-5577
lindal@puyallupwa.gov *Please note this is a new email address*

Permit Application Resource Page: <http://www.cityofpuyallup.org/325/Permit-Support-Services>

In matters of style, swim with the current; in matters of principle, stand like a rock. -T. Jefferson

Did you know that you can easily submit for a permit online? Introducing CityView, our new online permitting system. Go to the [City's website page here](#) for more information. Or, scan this QR code with your phone to learn more.



From: Brian Johnson <BrianJ@PuyallupWA.gov>
Sent: Thursday, April 7, 2022 2:27 PM
To: Linda Lian <LindaL@PuyallupWA.gov>
Subject: FW: PRSMS20210109

Linda –

I scaled the attached PDF and our water main is approximately 8-feet from the proposed pole replacement. If they excavated a 5-foot hole (centered on the pole) that should still leave over 5-feet of dirt between our water main and the excavation pit. I don't see any concern with this project moving forward.

Brian Johnson
City of Puyallup
Public Works
Water Division
253-405-0441

From: Linda Lian <Lindal@PuyallupWA.gov>
Sent: Thursday, April 7, 2022 10:29 AM
To: Brian Johnson <BrianJ@PuyallupWA.gov>
Subject: PRSMS20210109

Hi Brian,

The city is reviewing an application for large light pole at 812 N Meridian, permit application PRSMS20210109. The new pole will replace an existing light pole.

The reason for the email is the location of the water main and the excavation pit. Per the applicant: *For the pole itself the foundation is 3.5' diameter. I would presume 5'x5'x7' hole would be needed to install the foundation.* I believe the watermain is far enough away but I wanted to know if you think any specific conditions should be placed on the installation.

The attached drawing shows the distance between the water and pole, see enhanced plan view. And the restoration area.

Thanks Brian,

Linda Lian
Engineer Technician IV
253-841-5577
lindal@puyallupwa.gov **Please note this is a new email address**

Permit Application Resource Page: <http://www.cityofpuyallup.org/325/Permit-Support-Services>

In matters of style, swim with the current; in matters of principle, stand like a rock. -T. Jefferson

Did you know that you can easily submit for a permit online? Introducing CityView, our new online permitting system. Go to the [City's website page here](#) for more information. Or, scan this QR code with your phone to learn more.

