

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

| Date of Inspection: | Jun 09, 2022 | Inspection Result: | FAILED |
|-------------------------------------|--|--------------------|--------|
| Permit Number: Property Address: | B-19-0402 401 15TH AVE SE, PUYA | LLUP, WA 98372; | |
| | Howard S Wright 41 TI ~ GSH Renovate 1S Sleep/Care | • | |

BLDG/MECH/PLUMB

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1; provide D.O.H. approval letter.
 - 2 ; complete vertical grab bar in restroom as discussed with contractor.
 - 3 ; provide special inspection final letter at time of final.
 - 4 ; complete all plumbing boots at required sinks.
 - 5 ; complete install of hammer arrestors at clothes washing machine and icemaker.

6 ; provide install instructions for ice machine showing 1" air gap or provide backflow protection as per code.

7 ; provide backflow certifications at time of final.

Sincerely,





Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

King

Shannon King Building Inspector 2 ShannonK@PuyallupWA.gov (253) 840-6684