



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 09, 2022

Inspection Result: **FAILED**

Permit Number: B-19-0402

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

To construct: TI ~ GSH RENOVATE 1ST FL PATIENT WING FOREST PAVILION PATIENT SLEEP/CARE

BLDG/MECH/PLUMB

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide D.O.H. approval letter.
- 2 ; complete all plumbing boots at required sinks.
- 3 ; complete install of hammer arrestors at clothes washing machine and icemaker.
- 4 ; provide install instructions for ice machine showing 1" air gap or provide backflow protection as per code.
- 5 ; provide backflow certifications at time of final.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive, flowing style.

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684