



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 10, 2022

Inspection Result: PARTIAL PASS

Permit Number: B-20-0984

Property Address: 3500 S MERIDIAN ;

Contractor: ROD BANE MANAGEMENT DBA RBM 6668 E OLIVE AVE FRESNO, CA 93727

To construct: TI - EXISTING SEARS/ BUILDING INTO BOWLING & ARCADE VENUE ~ ROUND 1

BLDG/PLUMB/MECH

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide fire cover approval.
- 2 ; complete all ceiling grid requirements as discussed with contractor - not ready
- 2 1 ; provide positive attachment of diffusers to main and cross tee of suspended ceiling.
- 2 ; complete tie wires at speaker in ceiling grid and positive attachment of speaker below suspended ceiling as discussed with contractor.
- ok to cover except areas noted. (leave out 1 tile at diffusers and speakers to check attachment)

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684