

The applicant shall cut and cap the sanitary sewer lateral on the customer's side of the cleanout located at the property line, under the supervision of a City Inspector, prior to any demolition. The existing sewer lateral shall not be reused. The applicant shall request an inspection through the CityView portal. Utility inspections are required prior to backfilling.

The applicant shall cut and cap the water service on the customer's side of the water meter setter, under the supervision of a City Inspector, prior to any demolition. The applicant shall request an inspection through the CityView portal. The City Water Division shall perform the water meter removal. Contact Jeff Daschofsky at 253-841-5512 to schedule the water meter removal.

**City of Puyallup
Development
Engineering
APPROVED**

See permit conditions.

ycharitou
06/10/2022
8:32:07 AM



Tax Parcels

- Base Parcel
- Condominium

Notify Resident

City Limits

Stormwater Facilities

- Vault
- Stormwater Pipes
- Stormwater Inlets
- Sewer Main
- Sewer Manhole

Water Mains


- Less than 12"
- Hydrants

APPROVED PLAN
CITY OF PUYALLUP
PLANNING DIVISION

APPROVED BY: NComstock
DATE: 06/10/2022
CASE NO.: B-21-0994
CONDITIONS: N/A

Call Before You Dig. It's the law. Dial 811 or call 1-800-424-5555.

Prior to starting site work, request an erosion and sediment inspection through the CityView portal.



City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic

Map produced using City of Puyallup GIS web apps.
Date: 4/20/2022

The printed information was derived from digital databases within the City of Puyallup GIS Portal. The City of Puyallup cannot accept responsibility for any errors, omissions, or positional accuracy, and therefore, there are no warranties which accompany this product. Users of this information should review or consult the primary data and information sources to ascertain the usability of the information.