



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Comment Notice

Permit Application # PRCTI20220811

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Building Review (Reviewed By: David Leahy, (253)435-3618, DLeahy@PuyallupWA.gov)

- ◆ Not sure of the proposed occupant load for the floor but must show how all exits meet the requirements of 2018 IBC section 1016.2 especially with all but one utilizing stockrooms as intervening rooms. Page A001 of plans,
- ◆ Need to show the required wall bracing as the ceiling cannot brace the walls. Page A501 of plans
- ◆ Do not see this information on the plans. Page A601 of plans
- ◆ Do not see this information on the plans. Page A601 of plans.

To resubmit, you must address all comments and complete the [resubmittal form](#). Please note, partial resubmittals will be deemed incomplete and returned.

When you are ready to resubmit, you can do so by using the customer portal and uploading a “new version” of the submittal requirement. In addition, you will need to pay your resubmittal fee at the time of resubmittal.

Your resubmittal will not be processed until the fee has been paid.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov