



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Comment Notice

Permit Application # PRCTI20220739

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Building Review (Reviewed By: David Leahy, (253)435-3618, DLeahy@PuyallupWA.gov)

◆ This cover will need to be Engineered and meet all snow loading, seismic and wind requirements per the 2018 IBC. Provide engineering plans 24" X 36" and calculations. Will also need to provide all seating layout and an occupant loading for this area for review and approval and show how this will not affect the exiting of the current restaurant as well as the exiting of this area. No further review could be done at this time. Note on page A-101 of plans.

To resubmit, you must address all comments and complete the [resubmittal form](#). Please note, partial resubmittals will be deemed incomplete and returned.

When you are ready to resubmit, you can do so by using the customer portal and uploading a “new version” of the submittal requirement. In addition, you will need to pay your resubmittal fee at the time of resubmittal.

Your resubmittal will not be processed until the fee has been paid.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov