



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 28, 2022 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRFUP20220853

Property Address: 2603 5TH ST SE, PUYALLUP, WA 98374;

Contractor: COMCAST - PRINCE TELECOM LLC 410 VALLEY AVE NW PUYALLUP, WA 98371

To construct: Contractor to start on the southeast corner of 2609 5th St SE and go west for 100' and cont. north for 132' of 2" conduit and place Carson on 2603 5th St SE Property line. ~ 5.23.22 REFUND FOR \$60.00 AS ORIGINAL APPLICATION WAS INCORRECT (ROW) WHICH HAS AN ADDITIONAL \$60.00 (private) REPAIR FEE

On this day we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: The crew proceeded with trenching to install conduit from the pole on 27th to just east of the pole on 5th where they placed a new flush mount carson. Restoration will require regrading the area at the corner of 5th and 27th, remove excavated roots and rocks throughout the site including the large rocks left on top of the rockery, and place crushed rock to match existing at the carson location.

Corrections:

- 1 Regrade trenched area near the trees, remove roots and excavated rocks and place crushed to match existing at the carson location.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Cheryl Trimble

Cheryl Trimble

Engineer Tech II

CTrimble@PuyallupWA.gov

(253) 841-5464