



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 01, 2022

Inspection Result: PASSED

Permit Number: B-21-0544

Property Address: 4423 S MERIDIAN;

Contractor: PROBUILD CONSTRUCTION 12112 92ND AVE CT E PUYALLUP, WA
98373

To construct: TI ~ TANDOORI GRILLBLDG/PLUMB/MECH STE # 715

On this day we have inspected your construction for **Grease Interceptor Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: As-Builts have been received, clean out and sampling tee accessible, vent lines installed and not blocked, and GI has been serviced lately.

Corrections:

Sincerely,

Jason Little
Engineering Tech IV
JLittle@PuyallupWA.gov



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 435-3636