



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 03, 2022

Inspection Result: **FAILED WITH FEE**

Permit Number: B-21-0544

Property Address: 4423 S MERIDIAN;

Contractor: PROBUILD CONSTRUCTION 12112 92ND AVE CT E PUYALLUP, WA 98373

To construct: TI ~ TANDOORI GRILLBLDG/PLUMB/MECH STE # 715

On this day we have inspected your construction for **Fire Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: INSP FIRE FINAL BUILDING PERMI - No Comments

Corrections:

- 1 11:30 onsite, front door and rear door locked.
 1. Hood suppression test required
 2. Hood suppression required to be tied into Fire Alarm
 3. Not Ready per phone calls and emails
 4. Pay 130.00\$ reinspection fee prior to next inspection

Sincerely,

David Drake
Building Inspector II
DDrake@PuyallupWA.gov
(253) 864-4171