City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 01, 2022 Inspection Result: FAILED

Permit Number: B-21-0544

Property Address: 4423 S MERIDIAN;

Contractor: PROBUILD CONSTRUCTION 12112 92ND AVE CT E PUYALLUP, WA

98373

To construct: TI ~ TANDOORI GRILLBLDG/PLUMB/MECH STE # 715

On this day we have inspected your construction for **Fire Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 11:30 onsite, front door and rear door locked.
 - 1. Hood suppression test required
 - 2. Hood suppression required to be tied into Fire Alarm
 - 3. Not Ready per phone calls and emails
 - 4. Pay 130.00\$ reinspection fee prior to next inspection

Notes added 7/1/2022 Permit status for Fire Prevention See above and this list for Final Inspection PRFA20220997 Fire Alarm - Ready to issue fees required. PRFS20220608 Fire Sprinkler - Complete PRFS20220824 Hood Suppression - Outstanding corrections

Sincerely,



City of Puyallup

Kay Cockerham

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Ray Cockerham Building Code Official RayC@PuyallupWA.gov

(253) 841-5585