

Permit No: PRCTI20220811

COMMERCIAL - TENANT IMPROVEMENT/REMODEL

Puyallup, WA

Address: 3500 S MERIDIAN, Unit: 985, PUYALLUP, WA 98373
Parcel # 6021590070

Owner
CAFARO NORTHWEST PARTNERSHIP PO BOX 586 ANNANDALE, NJ 08801

Applicant

Andrew Harte 16 East 12th Street Cincinnati, OH 45202 (513) 317-4830 aharte@architecture359.com

Contractor

PINE RIDGE CONST MGMT LLC 1000 COMMERCE PARK DR ST 518 WILLIAMSPORT, PA 17701 (570) 505-3890 WA L&I #:Cameron Malchow 1000 Commerce Park Drive Williamsport, PA 17701 cmalchow@pineridgecm.com WA L&I #:

Description of Work

SCOPE OF WORK CONSISTS OF INTERIOR ALTERATIONS LIMITED TO DEMOLITION OF NON-STRUCTURAL ELEMENTS, CONSTRUCTION OF NON-LOADBEARING PARTITIONS, MODIFICATIONS TO AFFECTED CEILINGS, AND INSTALLATION OF SHELVING LESS THAN 5'9" AND MILLWORK. NO CHANGE OF USE IS PROPOSED. NO CHANGES TO BUILDING ENVELOPE. BLDG ONLY

Permit Types Commercial - Tenant Improvement/Remodel

Expiration Date: December 28, 2022

Building Components:

Quantity	Units	Description	Unit Cost	Subtotal Cost
23610	SQ FT	Mercantile	\$0.00	\$0.00
12	DIFFUSERS	Mechanical Ducts	\$0.00	\$0.00
			Total Value of Work:	\$0.00

Standard Conditions:

1. * Final approval by the Building Official is required prior to use or occupancy.* Work shall not proceed until the inspector has approved the stages of construction.* Surface storm water shall be diverted from the building site and shall not drain onto adjacent properties.* I hereby acknowledge that I have read this Permit/Application, that the information given is correct; that I am the owner or the duly authorized agent of the owner; that plans submitted herewith are in compliance with all applicable city, county and state laws and that all construction will proceed in accordance with said laws. This permit shall expire if work is not commenced with 180 days or if the work is suspended for a period of 180 days. Permits expire two years from issuance. * By leaving the contractor information section blank, I hereby certify further that contractors (general or subcontractors) will not be hired to perform any work in association with this permit. I also certify that if I do choose to hire a contractor (general or subcontractor) I will only hire those contractors that are licensed by the State of Washington. If you are a property owner, contractor or permittee and you are paying for someone to perform the work, they must have a valid contractor registration and the person(s) installing plumbing inside a structure must meet the plumbing certification requirements. If you have any questions

regarding these regulations, you may contact the Washington State Department of Labor and Industries or you can find more information on-line at: http://www.lni.wa.gov/TradesLicensing/Contractors/HireCon/default.asp

2. Fire Alarm Conditions

The system will only be considered existing provided, the original panel remains in same location, the original panel is not rewired, and if the original panel can be replaced like for like if required.

If there is an existing Remote annunciator on the exterior of the building, it is required to be moved inside the vestibule.

The Fire Alarm System is required to be monitored throughout construction. The System can be put into test for up to 8hrs a day. Anything longer than 8hrs will require Fire Code Officials approval and result in Fire Watch.

RTU'S will be required to be tested for shut down with fire alarm.

All maintenance and inspections are required to be completed prior to any inspections.

L&I Final required prior to Fire Final.

Fire Sprinkler Conditions

The Fire Sprinkler System is required to be functional and monitored throughout construction. The System can be put into test for up to 8hrs a day. Anything longer than 8hrs will require Fire Code Officials approval and result in Fire Watch.

All maintenance and inspections are required to be completed prior to any inspections.

All tampers will be tested at Fire Sprinkler Final.

Building Conditions

Comply with 2018 IFC and 2018 IBC.

Separate permits required for fire alarm and fire sprinkler systems.

Exit lighting test required contractor to provide light meter.

Fire extinguishers required per code.

A Knox box is required at the front entry on the exterior of the building.

PIV must have a Knox lock or approved lock with an extra key provided in Knox box.

All above items to be completed prior to fire final. Fire final required before building final.

All FACP and Riser Room signs are required to be installed and legible. Replace if necessary.

All Fire Lane No Parking signs shall be updated or replaced as needed.

Fire Lane stripping shall be updated as needed.

Address required

Schedule your inspection online through the City of Puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email prior to inspection for date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays.

David Drake 253-864-4171 ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant: Andrew Harte