



CITY OF PUYALLUP  
**Development & Permitting Services**  
 333 S. Meridian, Puyallup, WA 98371  
 (253) 864-4165  
[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

**Permit No:**  
 PRFA20220979

## FIRE ALARMS

Puyallup, WA

<b>Job Address</b>	Address: 300 RIVER RD, PUYALLUP, WA 98371 Parcel # 0420214010	<b>ISSUED</b> July 01, 2022
<b>Owner</b>	300 RIVER RD 7815 SOUTH TACOMA WAY TACOMA, WA 98409-3836	
<b>Applicant</b>	Emma Hyde Howe 3006 96th St S Lakewood, WA 98499 EMMAH@E2SYSTEMSLLC.COM	
<b>Contractor</b>	E-SQUARED SYSTEMS LLC PO BOX 731227 PUYALLUP, WA 98373 LINDSEYL@E2SYSTEMSLLC.COM WA L&I #:	
<b>Description of Work</b>	Install new potter afc-1000 addressable fire alarm panel in group b occupancy in remodeled building and in existing maintenance bay building. Install initiation and notification to Puyallup and state fire code requirements. Provide fire alarm visual and audible notification on exterior of building and throughout building space within scope. Provide smoke detection and pull stations throughout. Building is sprinkled. Provide fire alarm central monitoring via Telco Lines.	
<b>Permit Types</b>	Fire Alarms	
<b>Expiration Date:</b>	December 28, 2022	

**Building Components:**

Quantity	Units	Description	Unit Cost	Subtotal Cost
205	DEVICES	Fire Alarm and Detection System and Related Equipment, New	\$0.00	\$0.00
<b>Total Value of Work:</b>				\$0.00

**Standard Conditions:**

1. 1- APPOINTMENT REQUIRED FOR ALL INSPECTIONS
- 2- PROVIDE PLANS AND PERMIT ON SITE FOR INSPECTION.
- 3- COMPLETE LABOR AND INDUSTRIES INSPECTIONS PRIOR TO REQUESTING CITY INSPECTION.
- 4- A REMOTE ANNUNCIATOR LOCATED ON THE EXTERIOR OF THE MAIN ENTRANCE IN A WEATHER PROOF HOUSING REQUIRED.
- 5- EXTERIOR FIRE BELL REQUIRED OUTSIDE FIRE SPRINKLER ROOM.
- 6- DEVICE MAPS REQUIRED AT THE ANNUNCIATOR AND FIRE ALARM PANEL PRIOR TO CALLING IN FINAL. THE ANNUNCIATOR MAP WILL NEED TO BE WEATHERPROOF.
- 7- TOTAL COVERAGE IS REQUIRED; SUBJECT TO FIELD INSPECTION. COMPLY WITH NFPA 72, 2013
- 8- FIRE ALARM SYSTEM SHALL BE PLACARDED PER NFPA 72. THE UL CERTIFICATE SHALL BE POSTED AT TIME OF FINAL INSPECTION. THE SYSTEM WILL NEED TO BE UL CERTIFIED.
- 9- A PRE-TEST SHALL BE CONDUCTED AND A PRINT OUT OF THE LOCATION OF THE DEVICE, POINT NUMBER AND

DESCRIPTOR SHALL BE FURNISHED TO THE INSPECTOR AT FINAL.

10- FIRE SPRINKLER TAMPER VALVES AND PIV WILL BE REQUIRED TO BE TESTED AT INSPECTION. FIRE SPRINKLER CONTRACTOR TO BE ONSITE.

11- THE CITY OF PUYALLUP ALLOWS ONE FACP PER BUILDING. THE PANEL WILL NEED TO BE LARGE ENOUGH TO HANDLE MULTIPLE TENTANTS IF APPLICABLE.

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

**I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.**

**Applicant:**  
Emma Hyde Howe