



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Comment Notice

Permit Application # PRROW20220998

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Engineering Review (Reviewed By: Linda Lian, (253)841-5577, LindaL@PuyallupWA.gov)

- ♦ See TCP under the Traffic Control Plan submittal
- ♦ Please explain why a lane closure is necessary for the sidewalk panel replacement. If a lane of Valley Ave NW must be taken the work may be allowed Monday through Thursday 9AM-2PM only. TCP Sheet 1 of 2
- ♦ Provide a TCP for sidewalk closure. See City of Puyallup's TCP No. 06 Sidewalk Closure. TCP Sheet 1 of 2
- ♦ Provide a TCP for the signalized intersection. The TCP must show the correct lane configuration and any detour routes for vehicular traffic that is necessary. TCP sheet 2 of 2

To resubmit, you must address all comments and complete the [resubmittal form](#).

When you are ready to resubmit, you can do so using the customer portal, by uploading a “new version” of the submittal requirement. Please note, partial resubmittals will be deemed incomplete and returned.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov