

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

## **INSPECTION REPORT**

Date of Inspection:	Jul 11, 2022	Inspection Result:	FAILED
Permit Number: Property Address:	2 2 . 0200		
	•	24th st e Graham, WA 9 DM; INCREASE KITCHEN;	
	REMOVE CLASSROOM	& OFFICE. ~ STEP BY STE	PBLDG/MECH/PLUMB

On this day we have inspected your construction for **Exhaust Hood Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: INSP EXHAUST HOOD - No Comments

## Corrections:

1 1. Complete welding of pin holes in exhaust duct at hoods1;2;3 as discussed with contractor

Sincerely,

Shannon King Building Inspector 2 ShannonK@PuyallupWA.gov (253) 840-6684

King