



ADDENDUM ADD#6

Walmart
Puyallup, WA
WD Partners Job Number: WALGP0402

Date: June 24, 2022
To: Walmart Stores Inc
2001 SE 10th Street
Bentonville, AR 72716 USA
Attn : Kristen Dinger

The following information amends and supplements the original construction drawings and specifications and shall become part of the construction documents. All changes are identified on the drawings as Addendum, ADD#6, with delta 4 symbol.

N2 : ENVELOPE COMPLIANCE

1. Revised form in its entirety per clarification

A4 : ROOF PLAN AND DETAILS

1. Detail 2: Revise size, count and locations of RCU's and added size of gutter and downspout

A4.1 : EXPANSION WALL SECTION & ROOF DETAILS

1. Detail 8: Revised RCU locations and sizes

OP1.2 : EXPANSION WALL SECTIONS AND DETAILS

1. Detail 2: Removed parapet and added gutter and revised Isolation joint location per clarification
2. Detail 3: Added Washington State code verbage
3. Details 1,2 & 3: Added furring, insulation and type X gypsum board

S2 : ROOF FRAMING PLAN AND DETAILS

1. Coordinated roof equipment locations with refrigeration and approved Joist/Deck drawings.

M1 : ENLARGED MECHANICAL PLAN

1. Detail 1: Added note to clarify rooftop equipment scheduling information location.
2. Detail 1: Updated RCU locations and tags. Included clearance for RTU just for reference.

P1 : ENLARGED PLUMBING PLAN, DETAILS AND SCHEDULE

1. Roof Drain Calculations: Added size provided to directly compare with size required for gutter and downspout. Size provided exceed minimum requirements for both.

BAS1 : BUILDING AUTOMATION SYSTEM PLAN

1. Detail 2: Added note.

T 614 634 7000
F 614 634 7777

7007 Discovery Boulevard
Dublin, OH 43017

wdpartners.com

BAS3 : BUILDING AUTOMATION SYSTEM REFRIGERATION PLANS

1. 1/BAS3 – PICKUP REFRIGERATION BAS PLAN
Item #1 –Revised plan per CI#31001.

2/BAS3 – REFRIGERATION BAS ONE-LINE DIAGRAM (NOVAR/SPORLAN)
Item #1 –Revised one-line per CI#31001.

REFRIG BAS SYMBOLS
Item #1 –Added symbols per CI#31001.

BAS4 : BUILDING AUTOMATION SYSTEM REFRIGERATION SCHEDULES

1. RCU2 DISCHARGE AIR TEMPERATURE AND DEFROST PARAMETERS
Item #1 –Revised schedule per CI#31001.

RCU4 DISCHARGE AIR TEMPERATURE AND DEFROST PARAMETERS
Item #2 –Added schedule per CI#31001.

BAS5 : BUILDING AUTOMATION SYSTEM REFRIGERATION DETAILS

1. 4/BAS5 – KE2 CONTROLLER WIRING (WALK-IN, RCU)
Item #1 –Revised detail per CI#31001.

BAS6 : BUILDING AUTOMATION SYSTEM REFRIG LEAK DETECTION PLAN

1. 2/BAS6 – LEAK DETECTION AND ALARM ONE-LINE DIAGRAM
Item #1 –Revised one-line diagram per CI#31001.

R1 : PICKUP REFRIGERATION PLAN

1. 1/R1 – PICKUP REFRIGERATION PLAN
Item #1 –Revised entire plan per CI#31001.

2/R1 – ROOF PICKUP REFRIGERATION PLAN
Item #2 –Added plan to sheet per structural coordination.

KEYNOTES
Item #3 –Added keynote 15.620 per CI#31001.
Item #4. Removed keynotes per structural coordination.

PIPING SCHEDULE RCU2
Item #5 –Revised schedule per CI#31001.

PIPING SCHEDULE RCU3
Item #6 –Revised schedule per CI#31001.

PIPING SCHEDULE RCU4
Item #7 –Added schedule per CI#31001.

R2 : REFRIGERATION SCHEDULES

1. REFRIGERATION SCHEDULE SYSTEM RCU2
Item #1 –Revised schedule per CI#31001.

REFRIGERATION SCHEDULE SYSTEM RCU3
Item #2 –Revised schedule per CI#31001.

REFRIGERATION SCHEDULE SYSTEM RCU4
Item #3 –Added schedule per CI#31001.

OWNER FURNISHED WALK-IN EVAPORATOR COIL SCHEDULE
Item #4 –Revised schedule per CI#31001.

R3 : REFRIGERATION DETAILS

1. 1/R3 – NOT USED
Item #1 –Removed detail per CI#31001.
- 2/R3 – NOT USED
Item #2 –Removed detail per CI#31001.
- 3/R3 – NOT USED
Item #3 –Removed detail per CI#31001.
- 8/R3 – VERTICAL SUCTION DOUBLE RISER
Item #4 –Added detail per CI#31001.
- 9/R3 – DOUBLE SUCTION RISER ROOF PENETRATION
Item #5 –Added detail per CI#31001.

R4 : REFRIGERATION SUBMITTALS

1. Item #1 –Revised submittals per CI#31001.

E1 : ELECTRICAL PLANS, DETAILS AND SCHEDULES

1. Detail 1: Added detail callout number 7/E2.
2. Detail 2: Removed exterior wall mounted light fixture relocation scope.
3. Detail 4: Removed exterior wall mounted light fixtures.
4. Detail 4: Revised light fixture location to coordinate with evaporator location.
5. Keynote Schedule: Removed keynote number 16.131 and 16.133.
6. Light fixture schedule: Removed type 11 light fixture details.

E2 : PICKUP STORAGE POWER PLAN,NOTES AND DETAILS

1. Added detail callout number 7.
2. Detail 2: Revised pickup storage power plan as per refrigeration drawings.
3. Detail 5: Added BAS controller as per refrigeration drawings.
4. Feeder Schedule: Removed feeder number 103.
5. Keynote Schedule: Added keynote number 16.145, 16.233 and 16.530.

E3 : ELECTRICAL ONE-LINE, DETAILS AND SCHEDULES

1. Panel L4D1: Revised circuit number 2.
2. Panel LPU: Revised circuit numbers 1-6 and 15-26.
3. Revised MSB load summary.
4. Revised voltage drop of RCU-2, RCU-3 and added voltage drop calculations for RCU-4 and KE2-40 controllers.

OS1 : OWNER SUPPLIED ITEMS

1. Owner Supplied Items: Revise evaporator coil

Please contact me with any questions you may have at 614.634.7219

Sincerely,

Ben Dariano
Planning & Permitting

END OF ADDENDUM