



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 12, 2022

Inspection Result: **FAILED**

Permit Number: PRCTI20220562

Property Address: 302 33RD ST SE, PUYALLUP, WA 98372;

Contractor: RAYMOND HANDLING CONCEPTS CORP 41400 BOYCE ROAD
FREMONT, CA 94538 (562) 762-5636

To construct: Installation of storage racks into an existing building.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. finish bolting of mid brace between racks 2. provide engineers letter for embedment depth of hold downs not meet 3. provide load plaques and 3" flu spacing plaques per city approved plans

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590