

City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 13, 2022 Inspection Result: FAILED WITH FEE

Permit Number: PRSG20221026

Property Address: 3500 S MERIDIAN, Unit: 902, PUYALLUP, WA 98373;

Contractor: CLEARWAY SIGNS 9426 CANYON RD PUYALLUP, WA 98371 **To construct:** Installation of freestanding bowling pin sign for Round 1.

On this day we have inspected your construction for **Sign Footing Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1.provide city approved plans on site at time of inspection
 - 2.complete all rebar per city approved plans
 - 3.not ready
- 2 1.sleeve pipe thru footing as previously discussed with contractor
 - 2. Provide city approved plans at time of next inspection
 - 3.reconnect footing drain and protect from concrete pour
 - 4. Clean off existing concrete for bonding purpose to new concrete previously discussed with contractor

5.rebar needs to be a min of 3" from dirt

Sincerely,

Shannon King

Building Inspector 2



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

ShannonK@PuyallupWA.gov (253) 840-6684