



CITY OF PUYALLUP
Development & Permitting Services
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Permit No:
PRFS20221060

FIRE SPRINKLERS

Puyallup, WA

Job Address	Address: 3213 WILDWOOD PARK DR, PUYALLUP, WA 98374 Parcel # 0419023002	ISSUED July 13, 2022
Owner 3213 WILDWOOD PARK DR PO BOX 370 PUYALLUP, WA 98371-0156		
Applicant Darin Wall 1436 NW 53rd Street Seattle, WA 98107 (206) 482-8858 dwall@gowfire.com		
Contractor ALEXANDER GOW FIRE EQUIPMENT 1436 NW 53RD ST SEATTLE, WA 98107 WA L&I #:		
Description of Work Install Range Guard fire suppression system into kitchen hood		
Permit Types	Fire Sprinklers	
Expiration Date: January 09, 2023		

Building Components:

Quantity	Units	Description	Unit Cost	Subtotal Cost
1	QTY	Fire Suppression System other than Sprinklers	\$0.00	\$0.00
			Total Value of Work:	\$0.00

Standard Conditions:

- 1- PROVIDE PLANS AND PERMIT ON SITE FOR INSPECTION.
- 2- Testing is required for shunts, discharge, temperature, fire alarm, and as required by the manufacturer.

CONTRACTOR MUST BE PRESENT AT INSPECTIONS.

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether

Applicant:
Darin Wall

specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.