



City of Puyallup
Building Division
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Comment Notice

Permit Application # PRCTI20221032

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Building Review (Reviewed By: David Leahy, (253) 435-3168, DLeahy@PuyallupWA.gov)

1. Racks need to be designed to the current RMI ANSI/MH16.1 standards.
2. Need to specify actual manufacture of anchors being installed for these racks.
3. Need to provide ESR reports for the anchors being used.
4. Max. loading for each shelf needs to be designated on the plans and placards need to be posted for all loading per the above referenced standards.
5. Anchors will need to be special inspected during the installation process as just a pull test on anchors does not meet the required installations per any manufacture's reports or the IBC.
6. Need to clearly define the dimensions of all the uprights and shelf beams especially due to the seismic zone that we are in here.

To resubmit, you must address all comments and complete the [resubmittal form](#). Please note, partial resubmittals will be deemed incomplete and returned. The above information must be received by our office to deem this application complete. If the required information is not received within 30 days, your application will be canceled.

When you are ready to resubmit, you can do so using the CityView portal by uploading a "new version" of the submittal requirement and be sure to put the correct submittal document(s) to the correct type.

In addition, you will need to [pay your resubmittal fee at the time of resubmittal](#). Your resubmittal will not be processed until the fee has been paid.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov