

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Jul 18, 2022	Inspection Result:	FAILED
Permit Number: Property Address:	PRCTI20220562 302 33RD ST SE, PU	YALLUP, WA 98372;	
Contractor:	RAYMOND HANDLING CONCEPTS CORP 41400 BOYCE ROAD FREMOND, CA 94538 (562) 762-5636		
To construct:	Installation of storage	ge racks into an existing bu	ilding.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1.finish bolting of mid brace between racks 2.provide engineers letter for embedment depth of hold downs not meet 3.provide load plaques and 3"flu spacing plaques per city approved plans
- 2 1. Complete 3 inch load plaques Per city approved plans Or a letter from the engineer of record stating that the plaques are not required With a stamp

Sincerely,

Shannon King Building Inspector 2 ShannonK@PuyallupWA.gov (253) 840-6684



City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org