



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jul 18, 2022

**Inspection Result:** **FAILED**

**Permit Number:** B-21-0256

**Property Address:** 3303 8TH AVE SE ;

**Contractor:** David Douglas 13718 224th st e Graham, WA 98373 (253) 355-6122

**To construct:** TI ~ MODIFY BATHROOM; INCREASE KITCHEN; ADD STORAGE;  
REMOVE CLASSROOM & OFFICE. ~ STEP BY STEPBLDG/MECH/PLUMB

On this day we have inspected your construction for **Light Test For Grease Duct Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1.complete welding pin holes at hood 1;2;3 as discussed with contractor
- 2 1. Complete Welding of pinholes at hood 1
- 3 1. Hood one welding complete except on roof
- 4 1. Baxter duct repair pin holes

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)