



CITY OF PUYALLUP
Development & Permitting Services
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Permit No:
PRFA20221168

FIRE ALARMS

Puyallup, WA

Job Address	Address: 310 31ST AVE SE, PUYALLUP, WA 98374 Parcel # 0419033050	ISSUED August 03, 2022
Owner WAL-MART RE BUSINESS TR 2403 PROPERTY TAX DEPT PO BOX 8050 MS 0555 BENTONVILLE, AR 72716		
Applicant STEPHEN SMITH 2661 N PEARL ST, #351 Tacoma, WA 98407 (564) 200-1583 STEVE-PFS@OUTLOOK.COM		
Contractor PROGRESSIVE FIRE & SECURITY 2661 N PEARL ST, #351 TACOMA, WA 98407 (564) 200-1583 STEVE-PFS@OUTLOOK.COM WA L&I #:		
Description of Work T.I. add 14 devices in SE corner		
Permit Types	Fire Alarms	
Expiration Date: January 30, 2023		

Building Components:

Quantity	Units	Description	Unit Cost	Subtotal Cost
14	DEVICES	Fire Alarm and Detection System and Related Equipment, Alteration	\$0.00	\$0.00
			Total Value of Work:	\$0.00

Standard Conditions:

- 1- APPOINTMENT REQUIRED FOR ALL INSPECTIONS
- 2- PROVIDE PLANS AND PERMIT ON SITE FOR INSPECTION.
- 3- COMPLETE LABOR AND INDUSTRIES INSPECTIONS PRIOR TO REQUESTING CITY INSPECTION.
- 4- A REMOTE ANNUNCIATOR LOCATED AT MAIN ENTRANCE .
- 5- Update DEVICE MAPS REQUIRED AT THE ANNUNCIATOR AND FIRE ALARM PANEL PRIOR TO CALLING IN FINAL. THE ANNUNCIATOR MAP WILL NEED TO BE WEATHER PROOF.
- 6- TOTAL COVERAGE IS REQUIRED; SUBJECT TO FIELD INSPECTION. COMPLY WITH NFPA 72, 2013
- 7- FIRE ALARM SYSTEM SHALL BE PLACARDED PER NFPA 72. THE UL CERTIFICATE SHALL BE POSTED AT TIME OF FINAL INSPECTION. THE SYSTEM WILL NEED TO BE UL CERTIFIED.
- 8- A PRE-TEST SHALL BE CONDUCTED AND A PRINT OUT OF THE LOCATION OF THE DEVICE, POINT NUMBER AND DESCRIPTOR SHALL BE FURNISHED TO THE INSPECTOR AT FINAL.
- 9- THE CITY OF PUYALLUP ALLOWS ONE FACP PER BUILDING. THE PANEL WILL NEED TO BE LARGE ENOUGH TO HANDLE MULTIPLE TENTANTS IF APPLICABLE.

2. The subject property has been classified as a contaminated site by the Tacoma Pierce County Health Department (TPCHD) and must be remediated per Washington Administrative Code Title 173. It is the applicant's responsibility to coordinate cleanup with TPCHD. Visit <https://www.tpchd.org/healthy-places/contaminated-property-cleanup> for more information. The applicant shall request a remediation status report from TPCHD's Rob Olsen by emailing him at rolsen@tpchd.org. Provide a copy of the status report to the City.

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
STEPHEN SMITH