



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 03, 2022

**Inspection Result:** **FAILED**

**Permit Number:** PRPF20220743

**Property Address:** 1501 39TH AVE SW, PUYALLUP, WA 98373;

**Contractor:** ARIES BUILDING SYSTEMS LLC 4211 FACTORIA BLVD ST SE BELLEVUE,  
WA 98006 (425) 644-3571

**To construct:** Relocate one (1) existing dry portable to Kessler.

On this day we have inspected your construction for **Manufactured Or Modular Structure Setup** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

1. provide engineers fix or approval of slope of footing exceeding code

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590