



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 03, 2022                      **Inspection Result:**      **NOT READY**

**Permit Number:** PRCTI20220811

**Property Address:** 3500 S MERIDIAN, Unit: 985, PUYALLUP, WA 98373;

**Contractor:** PINE RIDGE CONST MGMT LLC 1000 COMMERCE PARK DR ST 518  
WILLIAMSPORT, PA 17701 (570) 505-3890 Cameron Malchow 1000  
Commerce Park Drive Williamsport, PA 17701

**To construct:** SCOPE OF WORK CONSISTS OF INTERIOR ALTERATIONS LIMITED TO  
DEMOLITION OF NON-STRUCTURAL ELEMENTS, CONSTRUCTION OF  
NON-LOADBEARING PARTITIONS, MODIFICATIONS TO AFFECTED  
CEILINGS, AND INSTALLATION OF SHELVING LESS THAN 5'9" AND  
MILLWORK. NO CHANGE OF USE IS PROPOSED. NO CHANGES TO  
BUILDING ENVELOPE. BLDG ONLY

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1. Talked about demo and overall project

**Corrections:**

- 1 1.remove flooring from under wall plates so it will bear on concrete
- 2.complete framing on door opening
- 3.complete all framing above mechanical equipment
- 4.complete all fasteners at studs to wall plates
- 5.verify that electrical J/Box in concrete are abandoned where new wall plates are placed
6. Provide architectural plans for all walls removed and demo
7. Remove all abandoned ducting, framing, electrical conduit thru out space

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Kevin Spruell

Building Inspector I

[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)

(253) 841-5590