

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Aug 03, 2022	Inspection Result:	NOT READY
Permit Number: Property Address:			
	0	224th st e Graham, WA 9 OM; INCREASE KITCHEN;	
	REMOVE CLASSROOM	& OFFICE. ~ STEP BY STE	PBLDG/MECH/PLUMB

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: INSP CEILING GRID/T-BAR INSPEC - No Comments

Corrections:

- 1 1.ok to cover perimeter only
 - 2. Provide positive connection of diffusers
 - 3. Complete grid around hoods
 - 4. Provide fire cover approval prior to next inspection

Sincerely,

Kevin Spruell Building Inspector I KSpruell@PuyallupWA.gov (253) 841-5590