



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 26, 2022

Inspection Result: PARTIAL PASS

Permit Number: B-21-0256

Property Address: 3303 8TH AVE SE ;

Contractor: David Douglas 13718 224th st e Graham, WA 98373 (253) 355-6122

To construct: TI ~ MODIFY BATHROOM; INCREASE KITCHEN; ADD STORAGE;
REMOVE CLASSROOM & OFFICE. ~ STEP BY STEPBLDG/MECH/PLUMB

On this day we have inspected your construction for **Light Test For Grease Duct Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1.hoods 1,2 and Baxter hood duct approved on roof

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684