



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 11, 2022

**Inspection Result:** NOT READY

**Permit Number:** B-21-0256

**Property Address:** 3303 8TH AVE SE ;

**Contractor:** David Douglas 13718 224th st e Graham, WA 98373 (253) 355-6122

**To construct:** TI ~ MODIFY BATHROOM; INCREASE KITCHEN; ADD STORAGE;  
REMOVE CLASSROOM & OFFICE. ~ STEP BY STEPBLDG/MECH/PLUMB

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1.ok to cover perimeter only
2. Provide positive connection of diffusers
3. Complete grid around hoods
4. Provide fire cover approval prior to next inspection
- 2 1. Provide positive connections to diffusers to grid

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590