



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

# Comment Notice

**Permit Application # PRSG20221184**

August 12, 2022

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

**Building Review** (Reviewed By: David Leahy, (253)435-3618, [DLeahy@PuyallupWA.gov](mailto:DLeahy@PuyallupWA.gov))

- ♦ If you are saying this length of sign only needs 4 fasteners then need to show exactly where they are to be located especially in this seismic zone. And they should be galvanized or stainless since located outside. Attachment page of plans.

**Planning Review** (Reviewed By: Gabriel Clark, (253)770-3330, [GClark@puyallupwa.gov](mailto:GClark@puyallupwa.gov))

- ♦ Please show lineal feet of building wall. Planning Comment.
- ♦ Please show measurement of lineal feet of building wall that the sign will be attached on site plan. Planning Correction
- ♦ Please see PMC 20.60.047 (1) (b) to measure the size of the tenant space.
- ♦ Correction, Site Plan, Pg. 2

To resubmit, you must address all comments and complete the [resubmittal form](#).

When you are ready to resubmit, you can do so using the customer portal, by **uploading a "new version" of the submittal requirement**. In addition, if any resubmittal fees have been assessed, **you will need to pay your resubmittal fee at the time of resubmittal**. **Your resubmittal will not be processed until the fee has been paid**. Please note, partial resubmittals will be deemed incomplete and returned.

The review team may have also added conditions to the permit application that are not listed above. The permit conditions can be found in the CityView portal. Please note, some of the conditions may need to be resolved prior to permit issuance.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

[permitcenter@puyallupwa.gov](mailto:permitcenter@puyallupwa.gov)