City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 17, 2022 Inspection Result: PASSED W/

CONDITIONS

Permit Number: PRUSR20221164

Property Address: 110 9TH ST SW, PUYALLUP, WA 98371;

Contractor: HARTS SERVICES 3510 S PINE ST TACOMA, WA 98409

To construct: Water Line Repair

On this day we have inspected your construction for **Engineering Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Sleeve under sidewalk was pushed through with no excavation.

Yard should be stabilized.

Note: Next time call for a job start inspection the day of to alleviate installment confusion.

Corrections:

Sincerely,

Jason Little Engineering Tech IV



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

JLittle@PuyallupWA.gov (253) 435-3636