



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 22, 2022 **Inspection Result:** **NOT READY**

Permit Number: PRCTI20220811

Property Address: 3500 S MERIDIAN, Unit: 985, PUYALLUP, WA 98373;

Contractor: PINE RIDGE CONST MGMT LLC 1000 COMMERCE PARK DR ST 518
WILLIAMSPORT, PA 17701 (570) 505-3890 Cameron Malchow 1000
Commerce Park Drive Williamsport, PA 17701

To construct: SCOPE OF WORK CONSISTS OF INTERIOR ALTERATIONS LIMITED TO
DEMOLITION OF NON-STRUCTURAL ELEMENTS, CONSTRUCTION OF
NON-LOADBEARING PARTITIONS, MODIFICATIONS TO AFFECTED
CEILINGS, AND INSTALLATION OF SHELVING LESS THAN 5'9" AND
MILLWORK. NO CHANGE OF USE IS PROPOSED. NO CHANGES TO
BUILDING ENVELOPE. BLDG ONLY

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1.remove flooring from under wall plates so it will bear on concrete
- 2.complete framing on door opening
- 3.complete all framing above mechanical equipment
- 4.complete all fasteners at studs to wall plates 5.verify that electrical J/Box in concrete are abandoned where new wall plates are placed
6. Provide architectural plans for all walls removed and demo
7. Remove all abandoned ducting, framing, electrical conduit thru out space
- 2 1 : inspection of of framing at exterior wall at s. e. corner only. (complete vapor barrier at exterior wall prior to inspection) not ready



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684