



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 23, 2022 **Inspection Result:** **PASSED**

Permit Number: B-21-0421

Property Address: 1201 39TH AVE SW, PUYALLUP, WA 98373;

Contractor: REFRIGERATION UNLIMITED LLC 5102 20TH ST E, STE 1 FIFE, WA 98424

To construct: REPLACING ROOFTOP UNITS LIKE FOR LIKE ~ COSTCO

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide balance report with o.s.a. at time of mechanical final inspection.
- 2 ; complete condensate drain at r.t.u. about tire shop.
- 3 ; paint gas pipe at r.t.u.'s on roof.
- 4 ; complete insulation at refrigeration line set on roof.
- 5 ; cap abandoned condensate drain of roof.
- 6 ; provide electrical final prior to mechanical final.
- 7 ; complete install of angle brace at unit above pharmacy.

Sincerely,

Monty Johnson
Sr Building Inspector
Monty@PuyallupWA.gov
(253) 770-3326



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org