



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 23, 2022 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20220811

Property Address: 3500 S MERIDIAN, Unit: 985, PUYALLUP, WA 98373;

Contractor: PINE RIDGE CONST MGMT LLC 1000 COMMERCE PARK DR ST 518
WILLIAMSPORT, PA 17701 (570) 505-3890 Cameron Malchow 1000
Commerce Park Drive Williamsport, PA 17701

To construct: SCOPE OF WORK CONSISTS OF INTERIOR ALTERATIONS LIMITED TO
DEMOLITION OF NON-STRUCTURAL ELEMENTS, CONSTRUCTION OF
NON-LOADBEARING PARTITIONS, MODIFICATIONS TO AFFECTED
CEILINGS, AND INSTALLATION OF SHELVING LESS THAN 5'9" AND
MILLWORK. NO CHANGE OF USE IS PROPOSED. NO CHANGES TO
BUILDING ENVELOPE. BLDG ONLY

On this day we have inspected your construction for **Slab/Insulation Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1.ok to hang SW wall only

Corrections:

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 840-6684