



# Summit Backflow Services

Summit Backflow Services  
 Summitbackflow1@gmail.com  
 (253)861-9845

FACILITY NAME WA State Fair Water Purveyor Puyallup  
 Commercial  Residential   
 SERVICE ADDRESS 110 9th Ave SW CITY Puyallup ZIP 98371  
 CONTACT NAME \_\_\_\_\_ PHONE ( ) \_\_\_\_\_ FAX ( ) \_\_\_\_\_  
 ASSEMBLY LOCATION Sullyville S of train station  
 HAZARD TYPE Premise Isolation DCVA  RPBA  PVBA  AG  OTHER \_\_\_\_\_  
 NEW INSTALL  EXISTING  REPLACEMENT  OLD SER. # \_\_\_\_\_ PROPER INSTALLATION? YES  NO   
 MAKE OF ASSEMBLY Watts MODEL 009 SERIAL NO. 24885 SIZE 3"

INITIAL TEST	DCVA / RPBA	DCVA / RPBA	RPBA	PVBA / SVBA
	CHECK VALVE NO.1	CHECK VALVE NO.2		AIR INLET
PASSED <input checked="" type="checkbox"/> FAILED <input type="checkbox"/>	LEAKED <input type="checkbox"/> _____ PSID	LEAKED <input type="checkbox"/> <u>Held tight</u> PSID	OPENED AT <u>2.2</u> PSID #1 CHECK <u>7.4</u> PSID AIR GAP OK? <u>Yes</u>	OPENED AT _____ PSID DID NOT OPEN <input type="checkbox"/>
NEW PARTS AND REPAIRS	CLEAN <input type="checkbox"/> REPLACE <input type="checkbox"/> PART _____ <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	CLEAN <input type="checkbox"/> REPLACE <input type="checkbox"/> PART _____ <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	CLEAN <input type="checkbox"/> REPLACE <input type="checkbox"/> PART _____ <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	CHECK VALVE HELD AT _____ PSID LEAKED <input type="checkbox"/> CLEANED <input type="checkbox"/> REPAIRED <input type="checkbox"/>
TEST AFTER REPAIRS	LEAKED <input type="checkbox"/> _____ PSID	LEAKED <input type="checkbox"/> _____ PSID	OPENED AT _____ PSID #1 CHECK _____ PSID	AIR INLET _____ PSID CHK VALVE _____ PSID

AIR GAP INSPECTION: Supply Pipe Diameter \_\_\_\_\_" Separation \_\_\_\_\_" Pass  Fail   
 REMARKS: \_\_\_\_\_ LINE PRESSURE 60 PSI  
 \_\_\_\_\_ CONFINED SPACE? \_\_\_\_\_  
 TESTER SIGNATURE: Sean Russell CERT. NO. B7315 TEST DATE 7/15/22  
 TESTER NAME PRINTED: Sean Russell TESTER PHONE # (253) 861-9845  
 REPAIRED BY (if different): \_\_\_\_\_ DATE \_\_\_\_\_  
 FINAL TEST BY (if different): \_\_\_\_\_ CERT. NO. \_\_\_\_\_ DATE \_\_\_\_\_  
 CALIBRATION DATE 02/04/22 MAKE/MODEL Mid-West 845-5 GAUGE # 05211558

**CITY OF PUYALLUP**

1100 - 39th Ave SE

Puyallup, WA 98374

Phone: 253-841-5524 Fax: 253-841-5437

**Backflow Prevention Assembly  
Test Report**

Mailing Address

WA STATE FAIR  
110 9th AVE SW  
Puyallup 98371

Account #:  
Last Test:  
ShutOff:  
Test Due:

Service Address

Address: Fair grounds  
Company:  
Hazard: Vendor Hook up  
Location: Concessions #22 By Green Gate

Serial #: A987623  
Manufacturer: WILKINS  
Model: 350XL  
Type: DC  
Size: 1"  
Hazard #: 0 of 0

Reduced Pressure Principle Assembly				RP <input type="checkbox"/>	DCDA <input type="checkbox"/>
Double Check Valve Assembly				DC <input checked="" type="checkbox"/>	RPDA <input type="checkbox"/>
				PVB <input type="checkbox"/>	Air Gap <input type="checkbox"/>
				SVB <input type="checkbox"/>	AVB <input type="checkbox"/>
	Check Valve #1	Check Valve #2	Relief Valve	PVB/SVB	
Initial Test	Leaked <input checked="" type="checkbox"/>	Leaked <input checked="" type="checkbox"/>	Did not Open <input type="checkbox"/>	AIR INLET	
	Closed Tight <input type="checkbox"/>	Closed Tight <input type="checkbox"/>	Opened at _____ PSID	Did not Open <input type="checkbox"/>	
Repairs	Cleaned <input checked="" type="checkbox"/>	Cleaned <input checked="" type="checkbox"/>	Cleaned <input type="checkbox"/>	CHECK VALVE	
	Replaced <input type="checkbox"/>	Replaced <input type="checkbox"/>	Replaced <input type="checkbox"/>	Leaked <input type="checkbox"/>	
Details				Held at _____ PSID	
				Cleaned <input type="checkbox"/>	
Final Test	Closed Tight <input checked="" type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/>	Opened at _____ PSID	AIR INLET	
	Held at 2.4 PSID	Held at 2.6 PSID		CHECK VALVE	
				Held at _____ PSID	

**Comments**  
Both checks had shavings from pipe and teflon tape. Flushed water line to clean debris and cleaned both checks - tested Good

The above report is certified to be true. *Earl Hilliker*

Line Pressure 46/65  
Meter Reading \_\_\_\_\_  
Held Backpressure \_\_\_\_\_  
#2 Shutoff \_\_\_\_\_  
Relief Valve Exercised \_\_\_\_\_

	Date/Time	Tester	Signature	Tester #	Test Kit	Passed	Failed
Initial Test	8-18-2022	Earl Hilliker	<i>Earl Hilliker</i>	B3635	01202413	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Repairs	8-18-2022	Earl Hilliker	<i>Earl Hilliker</i>			<input type="checkbox"/>	<input type="checkbox"/>
Final Test	8-18-2022	Earl Hilliker	<i>Earl Hilliker</i>	B3635	01202413	<input checked="" type="checkbox"/>	<input type="checkbox"/>

**CITY OF PUYALLUP**

1100 - 39th Ave SE

Puyallup, WA 98374

Phone: 253-841-5524 Fax: 253-841-5437

**Backflow Prevention Assembly  
Test Report**

Mailing Address

WA STATE FAIR  
110 9th AVE SW  
Puyallup 98371

Account #:

Last Test:

ShutOff:

Test Due:

Service Address

Address: Fair grounds

Company:

Hazard: Vendor Hook up

Location: Cow concessions #23 By Green Gate

Serial #: A988433

Manufacturer: WILKINS

Model: 350XL

Type: DC

Size: 1"

Hazard #: 0 of 0

Reduced Pressure Principle Assembly				RP <input type="checkbox"/>	DCDA <input type="checkbox"/>
Double Check Valve Assembly				DC <input checked="" type="checkbox"/>	RPDA <input type="checkbox"/>
				PVB <input type="checkbox"/>	Air Gap <input type="checkbox"/>
				SVB <input type="checkbox"/>	AVB <input type="checkbox"/>
	Check Valve #1	Check Valve #2	Relief Valve	PVB/SVB	
Initial Test	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Did not Open <input type="checkbox"/>	AIR INLET	
	Closed Tight <input checked="" type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/>	Opened at _____ PSID	Did not Open <input type="checkbox"/>	
	Held at 2.1 PSID	Held at 2.5 PSID		Opened at _____ PSID	
Repairs	Cleaned <input type="checkbox"/>	Cleaned <input type="checkbox"/>	Cleaned <input type="checkbox"/>	CHECK VALVE	
	Replaced <input type="checkbox"/>	Replaced <input type="checkbox"/>	Replaced <input type="checkbox"/>	Leaked <input type="checkbox"/>	
Details				Held at _____ PSID	
				Cleaned <input type="checkbox"/>	
				Replaced <input type="checkbox"/>	
Final Test	Closed Tight <input type="checkbox"/>	Closed Tight <input type="checkbox"/>	Opened at _____ PSID	AIR INLET	
	Held at _____ PSID	Held at _____ PSID		Opened at _____ PSID	
				CHECK VALVE	
				Held at _____ PSID	

Comments

The above report is certified to be true. *Earl Hilliker*

Line Pressure 46-165

Meter Reading \_\_\_\_\_

Held Backpressure \_\_\_\_\_

#2 Shutoff \_\_\_\_\_

Relief Valve Exercised \_\_\_\_\_

	Date/Time	Tester	Signature	Tester #	Test Kit	Passed	Failed
Initial Test	8-18-2022	Earl Hilliker	<i>Earl Hilliker</i>	83635	01202413	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Repairs						<input type="checkbox"/>	<input type="checkbox"/>
Final Test						<input type="checkbox"/>	<input type="checkbox"/>

**CITY OF PUYALLUP**

1100 - 39th Ave SE

Puyallup, WA 98374

Phone: 253-841-5524 Fax: 253-841-5437

**Backflow Prevention Assembly**

**Test Report**

Mailing Address

WA STATE FAIR  
110 9th AVE SW  
Puyallup 98371

Account #:

Last Test:

Shut Off:

Test Due:

Service Address

Address: Fair grounds  
Company:  
Hazard: Vendor Hook up  
Location: Concessions #24 By Green Gate

Serial #: A987688

Manufacturer: Wilkins

Model: 350XL

Type: DC

Size: 1"

Hazard #: 0 of 0

Reduced Pressure Principle Assembly				RP <input type="checkbox"/>	DCDA <input type="checkbox"/>
Double Check Valve Assembly				DC <input checked="" type="checkbox"/>	RPDA <input type="checkbox"/>
				PVB <input type="checkbox"/>	Air Gap <input type="checkbox"/>
				SVB <input type="checkbox"/>	AVB <input type="checkbox"/>
	Check Valve #1	Check Valve #2	Relief Valve	PVB/SVB	
Initial Test	Leaked <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>	Did not Open <input type="checkbox"/>	AIR INLET	
	Closed Tight <input type="checkbox"/>	Closed Tight <input type="checkbox"/>	Opened at _____ PSID	Did not Open <input type="checkbox"/>	
Repairs	Cleaned <input checked="" type="checkbox"/>	Cleaned <input checked="" type="checkbox"/>	Cleaned <input type="checkbox"/>	CHECK VALVE	
	Replaced <input type="checkbox"/>	Replaced <input type="checkbox"/>	Replaced <input type="checkbox"/>	Leaked <input type="checkbox"/>	
Details				Held at _____ PSID	
				Cleaned <input type="checkbox"/>	
Final Test	Closed Tight <input checked="" type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/>	Opened at _____ PSID	AIR INLET	
	Held at 2.2 PSID	Held at 2.0 PSID		Opened at _____ PSID	
				CHECK VALVE	
				Held at _____ PSID	

**Comments**  
cleaned both checks of pea gravel and pieces of pipe shavings and teflon tape once cleaned and pipe flushed tested good  
The above report is certified to be true. *Earl Hilliker*

Line Pressure 46-165  
Meter Reading \_\_\_\_\_  
Held Backpressure \_\_\_\_\_  
#2 Shutoff \_\_\_\_\_  
Relief Valve Exercised \_\_\_\_\_

	Date/Time	Tester	Signature	Tester #	Test Kit	Passed	Failed
Initial Test	8-18-2022	Earl Hilliker	<i>Earl Hilliker</i>	B3635	01202413	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Repairs	8-18-2022	Earl Hilliker	<i>Earl Hilliker</i>			<input type="checkbox"/>	<input type="checkbox"/>
Final Test	8-18-2022	Earl Hilliker	<i>Earl Hilliker</i>	B3635	01202413	<input checked="" type="checkbox"/>	<input type="checkbox"/>