



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 24, 2022 **Inspection Result:** **FAILED**

Permit Number: E-21-0066

Property Address: 3303 8TH AVE SE ;

Contractor: RW SCOTT CONSTRUCTION CO. <NO STREET ADDRESS> AUBURN,
WA 98001

To construct: SEWER EXTENSION

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: SEE CORRECTIONS!

Corrections:

- 1 Punch List "A"
 1. Finish sewer main install and all applicable aspects related.
 2. Stabilize area near ditch where SS c/o was placed.
 3. Sewer and all other corrections and/or AoF must be in place/corrected for E-21-0440 prior to this permits final acceptance.
 4. Remove asphalt/cold mix from stock pile area.
 5. Grade out stock pile area to maintain flow away from ditch and stabilize.
 6. Remove silt fence when stabilization has taken root.
 7. Concrete around monument is failing and needs to be replaced with proper concrete aggregate mix for high and heavy traffic areas.
 8. Seal entire concrete monument on 33rd and 5th after replacement.
- Stabilization should consist of seed and 2" thick straw or hydroseed and 2" thick straw.
- Punch List "B"
1. If sewer main is not going to be finished prior to occupancy an AoF should be taken.
 2. Need an AoF for as-builts.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by a series of vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends from the end of the signature to the right.

Jason Little
Engineering Tech IV
JLittle@PuyallupWA.gov
(253) 435-3636