



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 24, 2022

Inspection Result: **FAILED**

Permit Number: E-21-0440

Property Address: 3303 8TH AVE SE ;

Contractor: MOUNTAIN CONSTRUCTION INC. 7457 S MADISON TACOMA, WA
98409 Jeremy Patnoi 7457 S. Madison St. Tacoma, WA 98409

To construct: SEWER MODIFICATION AT THE EXISTING STEP BY STEP FACILITY ~ STEP
BY STEP

confirm fees pls

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: SEE CORRECTIONS!

Corrections:

1 Punch List "A"

1. GI needs to be cleaned and filled, inspector on site to verify.
2. ALL sewer c/o's need to be inspected, covers and caps removed prior.
3. ALL storm, including roof drains, need to be jetted and sumps vacced, inspector on site to verify.
4. ALL storm structures need to be grouted.
5. ALL landscape areas need to be soil amended, inspector on site to verify.
6. Need ALL disturbed areas stabilized.
7. Need water service RPBA cert.
8. Need fire line RPBA cert.
9. Need fire line final, tamper switches tested and passed by fire inspector, WSP form filled out, and bushes removed 3' minimum clear around hydrant and 10' around FDC.
10. Seal ALL trench patches, sewer and fire.

Punch List "B"

1. ALL existing septic drain field needs to be decommissioned.
2. Need storm, sewer, and water as-builts.



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

3. Need storm water maintenance agreement.
4. Finish all concrete when pedestrian re-outs are accessible.

Sincerely,

Jason Little
Engineering Tech IV
JLittle@PuyallupWA.gov
(253) 435-3636