



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 25, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: B-20-0993

Property Address: 3213 WILDWOOD PARK DR, PUYALLUP, WA 98374;

Contractor: PEASE & SONS PO BOX 44100 TACOMA, WA 98444

To construct: 10-CLASSRM ADDITION TO THE EXISTING JHS ~ FERRUCCI JHS*E-20-0612 CIVIL*

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; cancel per Dennis - not ready
- 2 5 rooms on 2nd fl - ok
- 3 1 ; complete all ceiling grid requirements as per city approved plans. - not ready
- 4 1. No corridor
2. Complete main bar tie wire at perimeter that exceeds 1 and 6
3. Ok to complete cut tiles
- 5 1. Not ready
- 6 1. ok to due perimeter only basement, 1st floor, 2nd floor corridor SE addition
2. complete all sealing of all fire rated penetrations
3. seal penetrations of plenum

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684