

MECHANICAL COMPLIANCE SUMMARY

2018 WSEC Compliance Forms for Commercial Buildings including Group R2, R3 & R4 over 3 stories and all R1

Administered by: ©2021 NEEA, All rights reserved

Project & Applicant Information	Project Title	South Hill Mall Leasing Office - 2018 WSEC	For Building Department Use:	Date: Oct 19, 2021
	Project Address	3500 S MERIDIAN ST 902 PUYALLUP, WA 98373		
	Applicant Name	Brian Pritchard		
	Applicant Phone	253-329-0512		
	Applicant Email	BPRITCHARD@COOLSYS.COM		
For questions about this report, contact WSEC Commercial Technical Support at 360-539-5300 or via email at com.techsupport@waenergycodes.com				

General Occupancy	All Commercial	General Building Use Type	Office, Other	Building Cond. Floor Area	1,680	
General Project Types	Alteration	New Building or Addition Mechanical Scope	Alteration Mechanical Scope	Single Zone Systems & Equipment	Project Cond. Floor Area	1,640
					Floors Above Grade	1
					Compliance Method	Not Selected
Mechanical Project Description	REMOVE AND REPLACE LIKE FOR LIKE 36000 BTU ROOF TOP UNIT. OLD UNIT IS FACTORY SPEC'D AT 564LBS AND NEW UNIT IS 602LBS. NEW UNIT HAS DEHUMIDIFICATION AND ECONOMIZED MIXED AIR.					

Mechanical Compliance Scope and Method	Project Type	Mechanical Scope	Economizer Exception(s) Applied?	DOAS Ventilation Provided?	Higher Equipment Efficiency Option Applied?	Equipment Efficiency Compliance Verification
	Alteration	Single Zone Systems & Equipment	Yes	No	NA	COMPLIES
Additional Efficiency Credits Included (AEC)	Higher equipment efficiency and fan FEG					
Does building include occupancy classifications requiring DOAS?	No		Does project include DOAS equipment?			No
Based on project scope do TSPR requirements apply?	No		Do all systems comply with Appendix D standard reference design or qualify for an exception to TSPR?			No

Scope & Space Conditioning	ALTERATION - SINGLE ZONE SYSTEMS & EQUIPMENT	Compliance Verification	COMPLIES
---------------------------------------	--	--------------------------------	----------


Single Zone Air Systems Category - Heat pump, packaged (PTHP, SPVHP, room)

Air Systems Summary Information								
System/Equip ID	Quantity of Items	Supply Airflow Control	Ventilation Standard	Ventilation CFM (Total if Multiple Items)	Ventilation Air Source	Paired with DOAS	Ventilation energy recovery	Energy Recovery Efficiency (%)
WSC036H4R0A		Constant volume	IMC Natural Ventilation	1,200	Integral			

Air Systems & Equipment - Cooling											
System/Equip ID	Cooling System/Equip Type	Specific Type	Cooling Capacity per item (Btu/h)	AEC Efficiency Multiplier	Econo Exception Multiplier (FL & PL)	Combined Efficiency Multiplier (AEC & Econo)	Proposed Cooling Efficiency	CE Units	Proposed Part Load Efficiency	PL Units	Efficiency Compliance Verification
WSC036H4R0A	Heat pump, vertical (SPVHP)	Single package, vertical	39,000	1	0	1	12.1	EER			COMPLIES

Air Systems & Equipment - Heating										
System/Equip ID	Heating System/Equip Type	Specific Type	Heat Pump Heating Capacity (Btu/h)	Cooling Capacity (Btu/h)	AEC Efficiency Multiplier	Proposed Heat Pump Heating Efficiency	HPH Units	Proposed Low OSA Temp Efficiency	LTH Units	Efficiency Compliance Verification
WSC036H4R0A	Heat pump, vertical (SPVHP), heating	Single package, vertical heat pump	35,500	39,000	1	3.5	COP			COMPLIES

Air Systems & Equipment Details		
System/Equip ID	Area(s) Served	Location In Project Documents - Plan/Detail #
WSC036H4R0A	LEASING OFFICE	HIGHLIGHTED ALL PAGES
System/Equip ID for a single or multiple items?: Single item		
Economizer Compliance Method: Air-side economizer provided		
WSEC Equip Efficiency Reference Table - Heating: Table C403.3.2(3) - Packaged Terminal and Vertical AC and HP		
WSEC Equip Efficiency Reference Table - Cooling: Table C403.3.2(3) - Packaged Terminal and Vertical AC and HP		



PRMH20221213

FULL SIZED PLANS, SPECIFICATIONS FOR UNITS OLD AND NEW AND ENGINEERING PACKET ALL PART OF THIS 37 PAGE DOCUMENT FOR THIS PROJECT FOR INSPECTORS AND CONTRACTOR.

STRUCTURAL ABBREVIATIONS

#	NUMBER OR POUNDS
AB	ANCHOR BOLT
ACI	AMERICAN CONCRETE INSTITUTE
ADDL	ADDITIONAL
ADJ	ADJACENT
AESS	ARCHITECTURALLY EXPOSED STRUCTURAL STEEL
AFF	ABOVE FINISH FLOOR
AISC	AMERICAN INSTITUTE OF STEEL CONSTRUCTION
ALT	ALTERNATE
ALUM	ALUMINUM
APA	AMERICAN PLYWOOD ASSOCIATION
ARCH	ARCHITECTURAL
ASTM	AMERICAN SOCIETY FOR TESTING AND MATERIALS
ASSY	ASSEMBLY
ATR	ALL THREAD ROD
ATRA	ALL THREAD ROD WITH ADHESIVE
AWS	AMERICAN WELDING SOCIETY
B/	BOTTOM OF
BF	BRACED FRAME
BLDG	BUILDING
BLKG	BLOCKING
BM	BEAM
BN	BOUNDARY NAIL
BOT	BOTTOM
BRBF	BUCKLING RESTRAINED BRACED FRAME
BRNG	BEARING
BSMT	BASEMENT
BTWN	BETWEEN
BU	BUILT-UP
C	CAMBER OR CHANNEL (AMERICAN STANDARD)
CANT	CANTILEVER
CIP	CAST IN PLACE
CG	CENTER OF GRAVITY
CGS	CENTER OF GRAVITY OF (PRESTRESSING) STEEL
CJ	CONTROL OR CONSTRUCTION JOINT
CJP	COMPLETE JOINT PENETRATION
CL	CENTERLINE
CLG	CEILING
CLR	CLEARANCE: CLEAR
CLSM	CONTROLLED LOW STRENGTH MATERIAL
CMU	CONCRETE MASONRY UNIT
COL	COLUMN
CONC	CONCRETE
CONN	CONNECTION
CONST	CONSTRUCTION
CONT	CONTINUOUS
COORD	COORDINATE
CSA	CONCRETE SCREW ANCHOR
d	PENNY (NAIL)
db	NOMINAL BAR DIAMETER
DBA	DEFORMED BAR ANCHOR
DBL	DOUBLE
DBO	DESIGNED BY OTHERS
DEG	DEGREE
DEMO	DEMOLISH; DEMOLITION
DF/L	DOUGLAS FIR-LARCH
DIA	DIAMETER
DIAG	DIAGONAL
DIM	DIMENSION
DIST	DISTANCE
DL	DEAD LOAD
DN	DOWN
DTL	DETAIL
DWG	DRAWING
(E)	EXISTING
EA	EACH
EB	EXPANSION BOLT
EF	EACH FACE
EJ	EXPANSION JOINT
EL	ELEVATION
ELEC	ELECTRICAL
EN	EDGE NAIL
EQ	EQUAL; EARTHQUAKE
EW	EACH WAY
EXT	EXTERIOR
EXTD	EXTEND; EXTENDED
f _c	28 DAY CONC COMPRESSIVE STRENGTH
FF	FINISH FLOOR
FN	FIELD NAIL
FLR	FLOOR
FDN	FOUNDATION
FOC	FACE OF CONCRETE
FOM	FACE OF MASONRY
FOS	FACE OF STUD
FT	FEET
FTG	FOOTING
GA	GAUGE
GALV	GALVANIZED
GLB	GLUE LAMINATED BEAM
GWB	GYPSUM WALL BOARD
HDG	HOT-DIP GALVANIZED
HDR	HEADER
HF	HEM-FIR
HORIZ	HORIZONTAL
HSA	HEADED STUD ANCHOR
HSS	HOLLOW STRUCTURAL SECTION
HT	HEIGHT
ID	INSIDE DIAMETER
IN	INCH
INT	INTERIOR
JST	JOIST
JT	JOINT
K	KIP(S) (1,000 POUNDS)
KSI	KIPS PER SQUARE INCH
L OR 2L	ANGLE OR DOUBLE ANGLE
LF	LINEAR FOOT
LL	LIVE LOAD
LLBB	LONG LEGS BACK TO BACK
LLH	LONG LEG HORIZONTAL
LLV	LONG LEG VERTICAL
LONG	LONGITUDINAL
LVL	LAMINATED VENEER LUMBER
LWC	LIGHT WEIGHT CONCRETE

MAX	MAXIMUM
MC	MISCELLANEOUS CHANNEL
MECH	MECHANICAL
MF	MOMENT FRAME
MFR	MANUFACTURER
MEP	MECHANICAL, ELECTRICAL, PLUMBING
MIN	MINIMUM
MIR	MIRROR
MISC	MISCELLANEOUS
MSA	MASONRY SCREW ANCHOR

(N)	NEW
NIC	NOT IN CONTRACT
NOM	NOMINAL
NTE	NOT TO EXCEED
NTS	NOT TO SCALE

OC	ON CENTER
OD	OUTSIDE DIAMETER
OPP	OPPOSITE
OWJ	OPEN WEB JOIST

PAF	POWER-ACTUATED FASTENER
PC	PRECAST
PCF	POUNDS PER CUBIC FOOT
PERP	PERPENDICULAR
PJP	PARTIAL JOINT PENETRATION
PL	PLATE
PLF	POUNDS PER LINEAL FOOT
PLYWD	PLYWOOD
PSI	POUNDS PER SQUARE INCH
PSF	POUNDS PER SQUARE FOOT
PT	PRESSURE TREATED OR POST TENSIONED
PVC	POLYVINYL CHLORIDE

QTY	QUANTITY
RAD	RADIUS
REF	REFERENCE
REF	REFERENCE ARCH DOCUMENTS
REINF	REINFORCING
REQD	REQUIRED
REV	REVISED, REVISION
RO	ROUGH OPENING

SC	SLIP CRITICAL
SER	STRUCTURAL ENGINEER OF RECORD
SHT	SHEET
SHTG	SHEATHING
SIM	SIMILAR
SLBB	SHORT LEGS BACK TO BACK
SMS	SHEET METAL SCREW
SOG	SLAB ON GRADE
SQ	SQUARE
SS	STAINLESS STEEL
SSL	SHORT SLOTTED (HOLES)
STD	STANDARD
STL	STEEL
SQ	SQUARE
SYM	SYMMETRICAL






T&B	TOP AND BOTTOM
T&G	TONGUE AND GROOVE
T/	TOP OF
TRANS	TRANSVERSE
TYP	TYPICAL

UNO	UNLESS NOTED OTHERWISE
URM	UNREINFORCED MASONRY
UT	ULTRASONIC TEST

VERT	VERTICAL
VIF	VERIFY IN FIELD
W/	WITH
W/O	WITHOUT
WD	WOOD
WF	WIDE FLANGE
WP	WORK POINT
WTS	WELDED THREADED STUDS
WWR	WELDED WIRE REINFORCING


STRUCTURAL DRAWING INDEX		
SHEET	DRAWING TITLE	PERMIT SET
S0.01	COVER SHEET	●
S0.02	BUILDING PLAN	●
S1.01	ROOF FRAMING PLAN	●
S8.01	MECHANICAL UNIT DETAILS	●

STRUCTURAL DRAWING SYMBOLS



DECKING SPAN DIRECTION


MATERIAL SYMBOLS



Approval of submitted plans is not an approval of omissions or oversight by this office or noncompliance with any applicable regulations of local government. The contractor is responsible for making sure that the building complies with all applicable building codes and regulations of the local government.

THE APPROVED CONSTRUCTION PLANS AND ALL ENGINEERING DOCUMENTS MUST BE POSTED ON THE JOB AT ALL INSPECTIONS IN A VISIBLE AND READILY ACCESSIBLE LOCATION.

FULL SIZED LEDGIBLE COLOR PLANS ARE REQUIRED TO BE PROVIDED BY THE PERMITTEE ON SITE FOR ALL INSPECTIONS MIN. PLAN SIZE 22 X 34



STRUCTURAL NOTES:

THE CONTRACTOR IS RESPONSIBLE FOR VERIFICATION AND CORRELATION OF ALL ITEMS AND WORK NECESSARY FOR COMPLETION OF THE PROJECT AS INDICATED BY THE CONTRACT DOCUMENTS. SHOULD ANY QUESTION ARISE REGARDING THE CONTRACT DOCUMENTS OR SITE CONDITIONS, THE CONTRACTOR SHALL REQUEST INTERPRETATION AND CLARIFICATION FROM THE ENGINEER BEFORE BEGINNING THE PROJECT. THE ABSENCE OF SUCH REQUEST SHALL SIGNIFY THAT THE CONTRACTOR HAS REVIEWED AND FAMILIARIZED HIMSELF WITH ALL ASPECTS OF THE PROJECT AND HAS COMPLETE COMPREHENSION THEREOF. THE CONTRACTOR SHALL BE RESPONSIBLE FOR CONFORMANCE TO ALL SAFETY REGULATIONS DURING CONSTRUCTION.

THE CONTRACT DRAWINGS AND SPECIFICATIONS REPRESENT THE FINISHED STRUCTURE. UNLESS OTHERWISE SPECIFICALLY NOTED, THEY DO NOT INDICATE THE METHOD OF CONSTRUCTION OR CONSTRUCTION LOADS. ONLY THE CONTRACTOR SHALL PROVIDE ALL METHODS, DIRECTION AND RELATED EQUIPMENT NECESSARY TO PROTECT THE STRUCTURE, WORKMEN AND OTHER PERSONS AND PROPERTY DURING CONSTRUCTION. THE CONTRACTOR SHALL, AT THEIR OWN EXPENSE, ENGAGE PROPERLY QUALIFIED PERSONS TO DETERMINE WHERE AND HOW TEMPORARY PRECAUTIONARY MEASURES SHALL BE USED AND INSPECT SAME IN THE FIELD. ANY MATERIAL NOT AS SPECIFIED OR IMPROPER MATERIAL INSTALLATION OR WORKMANSHIP SHALL BE REMOVED AND REPLACED WITH SPECIFIED MATERIAL IN A WORKMANLIKE MANNER AT THE CONTRACTOR'S EXPENSE.

THESE PLANS, SPECIFICATIONS, ENGINEERING AND DESIGN WORK ARE INTENDED SOLELY FOR THE PROJECT SPECIFIED HEREIN. MILLER CONSULTING ENGINEERS DISCLAIMS ALL LIABILITY IF THESE PLANS AND SPECIFICATIONS OR THE DESIGN, ADVICE AND INSTRUCTIONS ATTENDANT THERETO ARE USED ON ANY PROJECT OR AT ANY LOCATION OTHER THAN THE PROJECT AND LOCATION SPECIFIED HEREIN. OBSERVATION VISITS TO THE JOB SITE AND SPECIAL INSPECTIONS ARE NOT PART OF THE STRUCTURAL ENGINEER'S RESPONSIBILITY UNLESS THE CONTRACT DOCUMENTS SPECIFY OTHERWISE.

NON-STRUCTURAL PORTIONS OF PROJECT INCLUDING, BUT NOT LIMITED TO, PLUMBING, FIRE SUPPRESSION, ELECTRICAL, MECHANICAL, LAND USE, SITE PLANNING, EROSION CONTROL FLASHING AND WATER-PROOFING ARE BEYOND THE SCOPE OF THESE DRAWINGS AND ARE PROVIDED BY OTHERS.

BUILDING CODE
ALL PHASES OF THE WORK SHALL CONFORM TO THE 2019 OREGON STRUCTURAL SPECIALTY CODE (OSSC), BASED ON THE 2018 INTERNATIONAL BUILDING CODE (IBC), INCLUDING ALL REFERENCE STANDARDS, UNLESS NOTED OTHERWISE.

STRUCTURAL DESIGN CRITERIA
LIVE LOAD REDUCTION FOR BEAMS AND COLUMNS WAS NOT USED. DESIGN FOR MECHANICAL LOADS INCLUDES ONLY THOSE INDICATED ON STRUCTURAL DRAWINGS. THE FOLLOWING ARE THE DESIGN REQUIREMENTS:

STRUCTURAL DESIGN CRITERIA	
RISK CATEGORY	II
WIND DESIGN DATA	
BASIC DESIGN WIND SPEED (3 SEC GUST)	V = 97 MPH
EXPOSURE	B
SEISMIC DESIGN DATA	
IMPORTANCE FACTOR	I _e = 1.0
SPECTRAL RESPONSE ACCELERATIONS	SS = 1.264, S1 = 0.436
SITE CLASS	D
SPECTRAL RESPONSE COEFFICIENT	SDS = 1.011


City of Puyallup
Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic

City of Puyallup
Building
REVIEWED
FOR
COMPLIANCE

DLeahy
08/24/2022
11:04:14 AM

PRMH20221213



MILLER
CONSULTING
ENGINEERS

9600 SW Oak St | Suite 400
Portland, OR | 97223
503.246.1250 | miller-se.com

MECH UNIT REPLACEMENT
SOUTH HILL MALL
COOLSYS COMMERCIAL & INDUSTRIAL SOLUTIONS
3500 S MERIDIAN STREET
PUYALLUP, WASHINGTON

COPYRIGHT 2021
Miller Consulting Engineers, Inc.

LINE IS 2 INCHES
AT FULL SCALE
(IF NOT 2" - SCALE ACCORDINGLY)



DRAWN BY: BCH
CHECKED BY: PRA

MCE PROJECT NO: 211478
ISSUE DATE: 11.15.21

DESCRIPTION	DATE	REV.

SHEET CONTENT
COVER SHEET

SHEET
S0.01





BUILDING PLAN

NTS

City of Puyallup
Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic

PRMH20221213



MILLER
CONSULTING
ENGINEERS

9600 SW Oak St | Suite 400
Portland, OR | 97223
503.246.1250 | miller-se.com

MECH UNIT REPLACEMENT
SOUTH HILL MALL
COOLSYS COMMERCIAL & INDUSTRIAL SOLUTIONS
3500 S MERIDIAN STREET
PUYALLUP, WASHINGTON

COPYRIGHT 2021
Miller Consulting Engineers, Inc.

LINE IS 2 INCHES
AT FULL SCALE
(IF NOT 2" - SCALE ACCORDINGLY)

DRAWN BY: BCH
CHECKED BY: PRA




MCE PROJECT NO: 211478

ISSUE DATE: 11.15.21

REV.	DATE	DESCRIPTION

SHEET CONTENT
BUILDING PLAN

SHEET
S0.02



1 MECHANICAL UNIT - CURB ANCHORAGE
S8.01 1" = 1'-0"



2 MECHANICAL UNIT CROSS SECTION
S8.01 1" = 1'-0"

3 CLIP CONNECTION DETAIL
S8.01 6" = 1'-0"

**City of Puyallup
Development & Permitting Services
ISSUED PERMIT**

Building	Planning
Engineering	Public Works
Fire	Traffic

PRMH20221213



**MILLER
CONSULTING
ENGINEERS**

9600 SW Oak St | Suite 400
Portland, OR | 97223
503.246.1250 | miller-se.com

MECH UNIT REPLACEMENT
SOUTH HILL MALL
COOLSYS COMMERCIAL & INDUSTRIAL SOLUTIONS
3500 S MERIDIAN STREET
PUYALLUP, WASHINGTON

COPYRIGHT 2021
Miller Consulting Engineers, Inc.

LINE IS 2 INCHES
AT FULL SCALE
(IF NOT 2" - SCALE ACCORDINGLY)

DRAWN BY: BCH
CHECKED BY: PRA

MCE PROJECT NO: 211478

ISSUE DATE: 11.15.21

REV.	DATE	DESCRIPTION

SHEET CONTENT
MECHANICAL UNIT
DETAILS

SHEET
S8.01




STRUCTURAL CALCULATIONS

South Hill Mall Replacement Mechanical Units
3500 S Meridian Street, Puyallup, WA
Coolsys Commercial & Industrial Solutions

November 15, 2021
Project No. 211478
18 pages


Principal Checked: PRA



*** LIMITATIONS ***

Miller Consulting Engineers, Inc. was retained in a limited capacity for this project. This design is based upon information provided by the client, who is solely responsible for accuracy of same. No responsibility and or liability is assumed by or is to be assigned to the engineer for items beyond that shown on these sheets.

9600 SW Oak Street, Suite 400 | Portland, Oregon 97223 | 503.246.1250 | www.miller-se.com



PRMH20221213

Building Code: 2018 International Building Code
Soils Report: No **Soils Report by:** _____ **Dated:** _____
Soil Bearing: 1500 PSF **Retaining Walls:** No
Equivalent Fluid Pressure (active): N/A PCF **Passive bearing:** _____ PCF **Friction:** _____
Structural System: Building Structure
Vertical System: Wood framed Construction **Lateral Sys:** Flexible Diaphragm / Wood shearwalls

Basic Design Loads:	Element	Roof			
	Load Type	Dead			
	Value (PSF)	15			
	Load Type	Snow			
	Value (PSF)	25			
	Deflection Criteria	L/240			

Lateral Design Parameters:
Wind Design: ASCE 7-16 **Exposure:** B **Wind Speed (3 sec Gust):** 104 MPH

Importance Factors $I_w =$ 1.00 (ice) $I_E =$ 1.25 (seismic) $I_s =$ 1.10 (snow) $I_t =$ 1.10 (ice) **Risk Cat:** III

Seismic Design

Seismic design parameters are based on published values from the USGS web site.

Latitude: _____
Longitude: _____

2% PE in 50 years, 0.2 sec SA = Ss
 2% PE in 50 years, 1.0 sec SA = S1

(Site class B parameters are indicated on this page, for actual site class used in design, refer to seismic design summary)

Design Summary:

The scope of these structural calculations includes verification of structural systems to support a replacement mechanical unit and related anchorage

Replacement Unit Weight: = 602 lbs
 Old Unit weight = 564 lbs (To be removed)


City of Puyallup
 Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic

PRMH20221213



Project Name South Hill Mall Mechanical Unit Replacement **Project #** 211478
Location 3500 S Meridian Street, Puyallup, WA
Client Coolsys Commercial & IND Solutions
By ADJ **Ck'd** PRA **Date** 11/12/2021 **Page** 1 of 18



Member B

$$W = 602 \text{ lbs} / (5.82)(2) + (25 \text{ psf} + 15 \text{ psf}) (7.5/4) = 52 \text{ plf} + 75 \text{ plf} = 127 \text{ plf}$$


$$M = wL^2/8 = (127)(5.82^2)/8 = 538 \text{ ft lbs}$$

$$V = 127(5.82/2) = 370 \text{ lbs}$$

Member A

$$P = 370 \text{ lbs}$$

$$w = 40(2') = 80 \text{ plf}$$



$$R1=R2 = V = 370 + 80(7.5/2) = 670 \text{ lbs}$$

$$M = (670+517)(1.91/2) + 147(3.69/2)(1/2) = 1270 \text{ ft lbs}$$

(see following pages for angle design)

City of Puyallup
Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic

(E) L4 x 4 x 1/4 angles
each side of unit

PRMH20221213



9600 SW Oak St #400
Portland, OR 97223

503.246.1250
miller-se.com

Project Name South Hill Mall Mechanical Unit Replacement Project # 211478

Location 3500 S Meridian Street, Puyallup, WA

Client Coolsys Commercial & IND Solutions

By ADJ Ck'd PRA Date 11/12/2021 Page 2 of 18

Shape: L

Shape Capacity = 0.66 < 1.0


Size: L4X4X1/4

ASD

Pr =	0.00	k, axial compression load
Mr _x =	1.27	ft-k, strong axis moment
Mr _y =	0.00	ft-k, weak axis moment
Vr _x =	0.67	k, strong axis shear
Vr _y =	0.00	k, weak axis shear
Tr =	0.00	in-k, torsion
Vt =	0.00	k, shear due to torsion
K =	1.00	(Table C-C2.2, pg 16.1-240)
Lb _x =	3.69	ft
Lb _y =	3.69	ft
E =	29000	ksi
Fy =	36	ksi
Fu =	58	ksi
Ag =	1.94	in ²
I _x =	3	in ⁴
I _y =	3	in ⁴
r _x =	1.25	in
r _y =	1.25	in
r _z =	0.783	in
b =	4	in
d =	4	in
t =	0.25	in
S _x =	1.03	in ³
J =	0.0438	in ⁴
bl =	4	in
bs =	4	in
bl/bs =	1.00	leg length ratio
bl/t =	16.00	
bs/t =	16.00	
Ω _c =	1.67	(Section E1, pg 16.1-32)
Ω _b =	1.67	(Section F1, pg 16.1-46)
Ω _v =	1.67	(Section F1, pg 16.1-46)
φ _c =	0.9	(Section E1, pg 16.1-32)
φ _b =	0.9	(Section F1, pg 16.1-46)
φ _v =	0.9	(Section F1, pg 16.1-46)

Section is Compact in the leg for flexure
 Section is Noncompact in the long leg for compression
 Section is Noncompact in the short leg for compression

Axial Capacities, Chapters D and E				
Equal Legged Angle	N/A			
Tension Capacity, Chapter D N/A				
Connection: Welded connection				
U =	0.64 Table D3.1, pg 16.1-29			
Ae =	1.24 in ²			
Pn =	69.84 k			
Comp. Capacity, Chapter E N/A				
KL/r =	56.6			
L/r =	35			
Fcr =	30.42 ksi			
Pn =	59.02 k, (Section E3 pg 16.1-33)			
Flexural Capacity, Chapter F				
Strong Axis:				
Max. compression at toe				
Mnx =	3.23 ft-k			
Weak Axis:				
Max. compression at toe				
Mny =	3.23 ft-k			
Shear Capacity, Chapter G				
Cv =	1			
Awx =	1.00 in ²			
Awy =	1.00 in ²			
kv =	1.2			
Vnx =	21.60 k			
Vny =	21.60 k			
equation G2-1				
Allowable Capacities Rn / Ω (ASD); Rn * φ (LRFD)				
(LRFD)	Pc, k	Pc, k	Mc, ft-k	Vc, k
x-axis	35.34	41.82	1.93	12.9
y-axis	(compression)	(tension)	1.93	12.9
Interaction Equations:				
Shear capacity = 0.05 < 1.0 OK				
Pr/Pc =	0.00 < 0.2, Equation H1-1b controls			
	0.66 < 1.0 OK			
Equation H1-1b, AISC 13 ed., pg 16.1-70				
Use L4X4X1/4				



PRMH20221213



Steel Column/Beam Design - AISC 13th Addition

Member B

Shape: L

Shape Capacity = 0.29 < 1.0


Size: L4X4X1/4

ASD

Pr =	0.00	k, axial compression load
Mr _x =	0.54	ft-k, strong axis moment
Mr _y =	0.00	ft-k, weak axis moment
Vr _x =	0.37	k, strong axis shear
Vr _y =	0.00	k, weak axis shear
Tr =	0.00	in-k, torsion
Vt =	0.00	k, shear due to torsion
K =	1.00	(Table C-C2.2, pg 16.1-240)
Lb _x =	5.82	ft
Lb _y =	5.82	ft
E =	29000	ksi
Fy =	36	ksi
Fu =	58	ksi
Ag =	1.94	in ²
I _x =	3	in ⁴
I _y =	3	in ⁴
r _x =	1.25	in
r _y =	1.25	in
r _z =	0.783	in
b =	4	in
d =	4	in
t =	0.25	in
S _x =	1.03	in ³
J =	0.0438	in ⁴
bl =	4	in
bs =	4	in
bl/bs =	1.00	leg length ratio
bl/t =	16.00	
bs/t =	16.00	
Ω _c =	1.67	(Section E1, pg 16.1-32)
Ω _b =	1.67	(Section F1, pg 16.1-46)
Ω _v =	1.67	(Section F1, pg 16.1-46)
φ _c =	0.9	(Section E1, pg 16.1-32)
φ _b =	0.9	(Section F1, pg 16.1-46)
φ _v =	0.9	(Section F1, pg 16.1-46)

Section is Compact in the leg for flexure
 Section is Noncompact in the long leg for compression
 Section is Noncompact in the short leg for compression

Axial Capacities, Chapters D and E				
Equal Legged Angle	N/A			
Tension Capacity, Chapter D N/A				
Connection: Welded connection				
U =	0.64 Table D3.1, pg 16.1-29			
Ae =	1.24 in ²			
Pn =	69.84 k			
Comp. Capacity, Chapter E N/A				
KL/r =	89.2			
L/r =	56			
Fcr =	23.68 ksi			
Pn =	45.94 k, (Section E3 pg 16.1-33)			
Flexural Capacity, Chapter F				
Strong Axis:				
Max. compression at toe				
Mnx =	3.15 ft-k			
Weak Axis:				
Max. compression at toe				
Mny =	3.15 ft-k			
Shear Capacity, Chapter G				
Cv =	1			
Awx =	1.00 in ²			
Awy =	1.00 in ²			
kv =	1.2			
Vnx =	21.60 k			
Vny =	21.60 k			
equation G2-1				
Allowable Capacities Rn / Ω (ASD); Rn * φ (LRFD)				
(LRFD)	Pc, k	Pc, k	Mc, ft-k	Vc, k
x-axis	27.51	41.82	1.89	12.9
y-axis	(compression)	(tension)	1.89	12.9
Interaction Equations:				
Shear capacity = 0.03 < 1.0 OK				
Pr/Pc =	0.00 < 0.2, Equation H1-1b controls			
	0.29 < 1.0 OK			
Equation H1-1b, AISC 13 ed., pg 16.1-70				
Use L4X4X1/4				



PRMH20221213




9600 SW Oak St #400
Portland, OR 97223
503.246.1250
miller-se.com

Project Name South Hill Mall Mechanical Unit Replacement Project # 211478
 Location 3500 S Meridian Street, Puyallup, WA
 Client Coolsys Commercial & IND Solutions
 By ADJ Ck'd PRA Date 11/12/2021 Page 4 of 18

Check existing Trusses

Loads to trusses at mechanical unit



Truss loads with Old Unit:

$$P = (564/4) + 40(7.5/4)(5.82/2) + 80(7.5/2) = 519 \text{ lbs}$$

$$W1 = 7.5(40 \text{ psf}) = 300 \text{ plf}$$

$$W2 = 40(7.5/2 + 7.5/4) = 225 \text{ plf}$$

(see pages 6-9 for truss analysis estimating max moment and shear)

$$M_{\text{max}} = 59297 \text{ ft lbs}$$

$$V_{\text{max}} = 6032 \text{ lbs}$$

$$\Delta_{\text{max}} = 0.0669 \text{ in}$$

Truss loads with New Unit:

$$P = (602/4) + 40(7.5/4)(5.82/2) + 80(7.5/2) = 670 \text{ lbs}$$

$$W1 = 7.5(40 \text{ psf}) = 300 \text{ plf}$$

$$W2 = 40(7.5/2 + 7.5/4) = 225 \text{ plf}$$

$$M_{\text{max}} = 61742 \text{ ft lbs}$$

$$V_{\text{max}} = 6183 \text{ lbs}$$

$$\Delta_{\text{max}} = 0.0695 \text{ in}$$


Increase in load:

$$\Delta \text{Moment} = 61742 - 59297 / 59297 = 4.12\% < 5\% \text{ increase ok}$$

$$\Delta \text{Shear} = 6183 - 6032 / 6032 = 2.50\% < 5\% \text{ increase ok}$$

$$D_{\text{def}} = .0695 - 0.0669 / 0.0669 = 3.89\% < 5\% \text{ increase ok}$$

(E) 30CS 4 Trusses at 7'-6" oc ok



PRMH20221213



9600 SW Oak St #400
Portland, OR 97223

503.246.1250
miller-se.com

Project Name South Hill Mall Mechanical Unit Replacement Project # 211478

Location 3500 S Meridian Street, Puyallup, WA


Client Coolsys Commercial & IND Solutions

By ADJ Ck'd PRA Date 11/12/2021 Page 5 of 18

Beam length = 38.208 feet, E = 29000 ksi, I = 7995 inches⁴

EXISTING CONDITIONS

City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic



Input:

Beam Element: Length = 38.208 feet; E = 29000 ksi; I = 7995 inches⁴;
Pin Support: X = 0 feet;
Roller Support: X = 38.208 feet;

Point Load: X = 16.194 feet; P = -519 pounds;

Point Load: X = 22.014 feet; P = -519 pounds;

Analysis Data:

Beam Length = 38.208 feet
502 Nodes, 501 Beam Elements, 1004 Degrees of Freedom

Reactions:


X feet	Vert pounds	Rot pound-foot
0	6031.950	
38.208	6031.950	

Equilibrium:

	Force	Reaction	Error
Vert	-12063.900	12063.900	-0.000 pounds
Rot	230468.746	-230468.743	0.003 pound-foot

Min & Max values:

Min Shear	=	-6031.950 pounds	at	38.208 feet
Max Shear	=	6031.950 pounds	at	0 feet
Min Moment	=	-1.03e-08 pound-foot	at	38.208 feet
Max Moment	=	59297.048 pound-foot	at	19.066 feet
Min Rotation	=	-0.0004659 radians	at	38.208 feet
Max Rotation	=	0.0004659 radians	at	0 feet
Min Deflection	=	-0.066999 inches	at	19.066 feet
Max Deflection	=	0 inches	at	0 feet








Beam length = 38.208 feet, E = 29000 ksi, I = 7995 inches⁴

**CONDITIONS WITH REPLACEMENT
MECHANICAL UNIT**

City of Puyallup
Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic



Input:

Beam Element: Length = 38.208 feet; E = 29000 ksi; I = 7995 inches^4;
Pin Support: X = 0 feet;
Roller Support: X = 38.208 feet;

Point Load: X = 16.194 feet; P = -670 pounds;

Point Load: X = 22.014 feet; P = -670 pounds;

Analysis Data:

Beam Length = 38.208 feet
502 Nodes, 501 Beam Elements, 1004 Degrees of Freedom

Reactions:


X feet	Vert pounds	Rot pound-foot
0	6182.950	
38.208	6182.950	

Equilibrium:

	Force	Reaction	Error
Vert	-12365.900	12365.900	-0.000 pounds
Rot	236238.154	-236238.151	0.003 pound-foot

Min & Max values:

Min Shear	=	-6182.950 pounds	at	38.208 feet
Max Shear	=	6182.950 pounds	at	0 feet
Min Moment	=	4.254e-09 pound-foot	at	0 feet
Max Moment	=	61742.342 pound-foot	at	19.066 feet
Min Rotation	=	-0.0004827 radians	at	38.208 feet
Max Rotation	=	0.0004827 radians	at	0 feet
Min Deflection	=	-0.069528 inches	at	19.066 feet
Max Deflection	=	0 inches	at	0 feet



Search Information

Address: 3500 S Meridian, Puyallup, WA 98373, USA
Coordinates: 47.15796110000001, -122.2965855
Elevation: 433 ft
Timestamp: 2021-11-01T21:03:38.758Z
Hazard Type: Wind



ASCE 7-16


MRI 10-Year 67 mph
 MRI 25-Year 73 mph
 MRI 50-Year 78 mph
 MRI 100-Year 82 mph
 Risk Category I 92 mph
 Risk Category II 97 mph
 Risk Category III 104 mph
 Risk Category IV 108 mph

ASCE 7-10

MRI 10-Year 72 mph
 MRI 25-Year 79 mph
 MRI 50-Year 85 mph
 MRI 100-Year 91 mph
 Risk Category I 100 mph
 Risk Category II 110 mph
 Risk Category III-IV 115 mph

ASCE 7-05

ASCE 7-05 Wind Speed 85 mph



The results indicated here DO NOT reflect any state or local amendments to the values or any delineation lines made during the building code adoption process. Users should confirm any output obtained from this tool with the local Authority Having Jurisdiction before proceeding with design.

Disclaimer

Hazard loads are interpolated from data provided in ASCE 7 and rounded up to the nearest whole integer. Per ASCE 7, islands and coastal areas outside the last contour should use the last wind speed contour of the coastal area – in some cases, this website will extrapolate past the last wind speed contour and therefore, provide a wind speed that is slightly higher. NOTE: For queries near wind-borne debris region boundaries, the resulting determination is sensitive to rounding which may affect whether or not it is considered to be within a wind-borne debris region.

Mountainous terrain, gorges, ocean promontories, and special wind regions shall be examined for unusual wind conditions.

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in the report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the

Search Information

Address: 3500 S Meridian, Puyallup, WA 98373, USA
Coordinates: 47.15796110000001, -122.2965855
Elevation: 433 ft
Timestamp: 2021-11-01T21:04:20.581Z
Hazard Type: Seismic
Reference Document: ASCE7-16
Risk Category: III
Site Class: D-default




Basic Parameters

Name	Value	Description
S_S	1.264	MCE_R ground motion (period=0.2s)
S_1	0.436	MCE_R ground motion (period=1.0s)
S_{MS}	1.516	Site-modified spectral acceleration value
S_{M1}	* null	Site-modified spectral acceleration value
S_{DS}	1.011	Numeric seismic design value at 0.2s SA
S_{D1}	* null	Numeric seismic design value at 1.0s SA

* See Section 11.4.8

Additional Information

Name	Value	Description
SDC	* null	Seismic design category
F_a	1.2	Site amplification factor at 0.2s
F_v	* null	Site amplification factor at 1.0s
CR_S	0.914	Coefficient of risk (0.2s)
CR_1	0.898	Coefficient of risk (1.0s)
PGA	0.5	MCE_G peak ground acceleration
F_{PGA}	1.2	Site amplification factor at PGA
PGA_M	0.6	Site modified peak ground acceleration



T _L	6	Long-period transition period (s)
SsRT	1.264	Probabilistic risk-targeted ground motion (0.2s)
SsUH	1.383	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
SsD	1.5	Factored deterministic acceleration value (0.2s)
S1RT	0.436	Probabilistic risk-targeted ground motion (1.0s)
S1UH	0.485	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
S1D	0.6	Factored deterministic acceleration value (1.0s)
PGAd	0.5	Factored deterministic acceleration value (PGA)


* See Section 11.4.8

The results indicated here DO NOT reflect any state or local amendments to the values or any delineation lines made during the building code adoption process. Users should confirm any output obtained from this tool with the local Authority Having Jurisdiction before proceeding with design.

Disclaimer

Hazard loads are provided by the U.S. Geological Survey [Seismic Design Web Services](#).

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in the report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the report.



Mechanical Unit Curb

Geometry


	Mech. Unit	
Unit Length, L_U =	69.84	in Long Direction
Unit Width, W_U =	47.52	in Short Direction
Unit Height, H_U =	40.92	in
Unit CoG, CoG_U =	20.46	in

Curb

Curb Length, L_C =	65.84	in Long Direction
Curb Width, W_C =	43.52	in Short Direction
Curb Height, H_C =	16	in
Curb Gauge =	18	Ga. = 0.0478"

Location

Location =	Outdoors	
Location =	Roof	
Roof Height =	28	ft
z =	28	ft Unit Base Elevation
Building Height, h =	28	ft
Building Length, L =	180	ft
Building Width, B =	250	ft



Forces

Gravity

Unit Weight, M_U =	785	lbs (NOTE: Actual unit weight reported by the client is 602 lbs)
Curb Weight, M_C =	47	lbs


Seismic

Life Safety?	No	ASCE 7-16 Section 13.1.3
S_{DS} =	1.011	g
a_p =	2.5	ASCE 7-16 Table 13.6-1
R_p =	6	ASCE 7-16 Table 13.6-1
Ω_o =	2	ASCE 7-16 Table 13.6-1

Wind

Site Elevation =	433	ft
Wind Speed =	97	mph ASCE 7-16 Figure 26.5-1
Wind Exposure =	B	ASCE 7-16 Section 26.7.36

785



PRMH20221213



9600 SW Oak St #400
Portland, OR 97223

503.246.1250
miller-se.com

Project Name South Hill Mall Mechanical Unit Replacement Project # 211478

Location 3500 S Meridian Street, Puyallup, WA

Client Coolsys Commercial & IND Solutions

By ADJ Ck'd PRA Date 11/12/2021 Page 13 of 18

Seismic ASCE 7-16 Chapter 13

(LRFD)

$I_p =$	1.0		
$F_p =$	0.607	W_p	ASCE 7-16 Equation 13.3-1
$F_{p,MAX} =$	1.618	W_p	ASCE 7-16 Equation 13.3-2
$F_{p,MIN} =$	0.303	W_p	ASCE 7-16 Equation 13.3-3
$e_H =$	0.607	W_p	
$e_V =$	0.202	W_p	$= 0.2S_{DS}$

Wind ASCE 7-16 Chapter 29

$K_z =$	0.69		ASCE 7-16 Table 26.10-1
$K_d =$	0.85		ASCE 7-16 Table 26.6-1
$K_1 =$	0		ASCE 7-16 Table 26.8-1
$K_2 =$	1		ASCE 7-16 Table 26.8-1
$K_3 =$	1		ASCE 7-16 Table 26.8-1
$K_{zt} =$	1		ASCE 7-16 Table 26.8-1
$K_e =$	0.984		ASCE 7-16 Table 26.9-1
$q_z =$	13.85	psf	ASCE 7-16 Equation 26.10-1
Unit Side Area, $A_r =$	14	ft ²	
Building Roof Area, $B_h =$	784	ft ²	
$GC_r =$	1.900	Horiz.	ASCE 7-16 Section 29.4
Unit Plan Area, $A_r =$	23	ft ²	
Building Roof Area, $BL =$	45000	ft ²	
$GC_r =$	1.500	Vertical	ASCE 7-16 Section 29.4
$w_H =$	26.31	psf	$= q_z GC_f$
$w_V =$	20.77	psf	$= q_z GC_r$


Mechanical Unit Forces:

(ASD)

$V_{SEISMIC} = 0.7e_H M_u$ $= 0.7(0.607)(785 \text{ lbs})$ $= 333 \text{ lbs}$	$V_{WIND, LONG} = 0.6w_H W_U H_U$ $= 0.6(26.31 \text{ psf})(47.52'')(40.92'')$ $= 213 \text{ lbs}$
$Uplift_{WIND} = 0.6w_V L_U W_U$ $= 0.6(20.77 \text{ psf})(70'')(47.52'')$ $= 287 \text{ lbs}$	$V_{WIND, SHORT} = 0.6w_H L_U H_U$ $= 0.6(26.31 \text{ psf})(70'')(40.92'')$ $= 313 \text{ lbs}$

Curb Forces:

$V_{SEISMIC} = 0.7e_H M_C$ $= 0.7(0.607)(47 \text{ lbs})$ $= 20 \text{ lbs}$	$V_{WIND, LONG} = 0.6w_H H_C W_C$ $= 0.6(26.31 \text{ psf})(16'')(43.52'')$ $= 76 \text{ lbs}$
	$V_{WIND, SHORT} = 0.6w_H H_C L_C$ $= 0.6(26.31 \text{ psf})(16'')(65.84'')$ $= 115 \text{ lbs}$



PRMH20221213



9600 SW Oak St #400
Portland, OR 97223

503.246.1250
miller-se.com

Project Name South Hill Mall Mechanical Unit Replacement Project # 211478

Location 3500 S Meridian Street, Puyallup, WA

Client Coolsys Commercial & IND Solutions

By ADJ Ck'd PRA Date 11/12/2021 Page 14 of 18

Unit to Curb

(ASD)

$$\begin{aligned} \text{Seismic } M_{OT} &= (\text{Unit } V_{SEISMIC})CoG_U \\ &= (333 \text{ lbs})(20.46'') \\ &= 568 \text{ lbs-ft} \end{aligned}$$

Long Direction

$$\begin{aligned} M_R &= M_U L_U / 2 \\ &= (785 \text{ lbs})(69.84'') / 2 \\ &= 2284 \text{ lbs-ft} \end{aligned}$$

$$\begin{aligned} \text{Wind } M_{OT} &= (\text{Unit } V_{WIND, LONG})H_U / 2 \\ &= (213 \text{ lbs})(40.92'') / 2 \\ &= 363 \text{ lbs-ft} \end{aligned}$$

Short Direction

$$\begin{aligned} M_R &= M_U W_U / 2 \\ &= (785 \text{ lbs})(47.52'') / 2 \\ &= 1554 \text{ lbs-ft} \end{aligned}$$

$$\begin{aligned} \text{Wind } M_{OT} &= (\text{Unit } V_{WIND, SHORT})H_U / 2 \\ &= (313 \text{ lbs})(40.92'') / 2 \\ &= 534 \text{ lbs-ft} \end{aligned}$$

Curb to Structure

(ASD)

$$\begin{aligned} \text{Seismic } M_{OT} &= (\text{Unit } V_{SEISMIC})(CoG_U + H_C) + (\text{Curb } V_{SEISMIC})(H_C / 2) \\ &= (333 \text{ lbs})(20.46'' + 16'') + 16'' + (20 \text{ lbs})(16'') / 2 \\ &= 1026 \text{ lbs-ft} \end{aligned}$$

Long Direction

$$\begin{aligned} M_R &= (M_U + M_C)L_C / 2 \\ &= (785 \text{ lbs} + 47 \text{ lbs})(65.84'') / 2 \\ &= 2284 \text{ lbs-ft} \end{aligned}$$

$$\begin{aligned} \text{Wind } M_{OT} &= (\text{Unit } V_{WIND, LONG})(H_U / 2 + H_C) + (\text{Curb } V_{WIND, LONG})(H_C / 2) \\ &= (213 \text{ lbs})(40.92'' / 2 + 16'') + (76 \text{ lbs})(16'') / 2 \\ &= 698 \text{ lbs-ft} \end{aligned}$$

Short Direction

$$\begin{aligned} M_R &= (M_U + M_C)L_C / 2 \\ &= (785 \text{ lbs} + 47 \text{ lbs})(43.52'') / 2 \\ &= 1509 \text{ lbs-ft} \end{aligned}$$

$$\begin{aligned} \text{Wind } M_{OT} &= (\text{Unit } V_{WIND, SHORT})(H_U / 2 + H_C) + (\text{Curb } V_{WIND, SHORT})(H_C / 2) \\ &= (313 \text{ lbs})(40.92'' / 2 + 16'') + (115 \text{ lbs})(16'') / 2 \\ &= 1029 \text{ lbs-ft} \end{aligned}$$

City of Puyallup
Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic

PRMH20221213



9600 SW Oak St #400
Portland, OR 97223

503.246.1250
miller-se.com

Project Name South Hill Mall Mechanical Unit Replacement Project # 211478

Location 3500 S Meridian Street, Puyallup, WA

Client Coolsys Commercial & IND Solutions

By ADJ Ck'd PRA Date 11/12/2021 Page 15 of 18

Load Summary

(ASD)


Wind Uplift = lbs

Unit to Curb:

Direction	Long Dir.	Short Dir.	
Seismic	333	333	lbs
Wind	213	313	lbs
Unit M _R	2284	1554	lbs-ft
Seismic M _{OT}	568	568	lbs-ft
Wind M _{OT}	363	534	lbs-ft

Curb to Roof:

Direction	Long Dir.	Short Dir.	
Seismic	353	353	lbs
Wind	289	429	lbs
Unit M _R	2284	1509	lbs-ft
Seismic M _{OT}	1026	1026	lbs-ft
Wind M _{OT}	698	1029	lbs-ft



PRMH20221213



9600 SW Oak St #400
Portland, OR 97223

503.246.1250
miller-se.com

Project Name South Hill Mall Mechanical Unit Replacement Project # 211478

Location 3500 S Meridian Street, Puyallup, WA

Client Coolsys Commercial & IND Solutions

By ADJ Ck'd PRA Date 11/12/2021 Page 16 of 18

Unit to Curb Anchorage

(ASD)

Short Direction Anchorage Forces

Seismic

Anchors Resisting Shear = 2 anchors
 $V = (278 \text{ lbs}) / (2 \text{ anchors})$
 $V = 139 \text{ lbs/anchor}$
 Anchors Resisting Overturning Tension = 2 anchors
 Overturning Arm = 47.52 in
 $T = [(0.6 - 0.202)(1554 \text{ lbs-ft}) - (474 \text{ lbs-ft})] / (47.52 \text{ in}) / 2 \text{ anchors}$
 $T = 0 \text{ lbs/anchor, No Uplift}$

Wind

Anchors Resisting Shear = 2 anchors
 $V = (313 \text{ lbs}) / (2 \text{ anchors})$
 $V = 157 \text{ lbs/anchor}$
 Anchors Resisting Overturning Tension = 2 anchors
 Overturning Arm = 47.52 in
 $T = [0.6(1554 \text{ lbs-ft}) - (534 \text{ lbs-ft})] / (47.52 \text{ in}) / (2 \text{ anchors}) - (287 \text{ lbs}) / 2(2 \text{ anchors})$
 $T = 21 \text{ lbs/anchor, No Uplift}$


Long Direction Anchorage Forces

Seismic

Anchors Resisting Shear = 4 anchors
 $V = (278 \text{ lbs}) / (4 \text{ anchors})$
 $V = 139 \text{ lbs/anchor}$
 Anchors Resisting Overturning Tension = 1 anchors
 Overturning Arm = 69.84 in
 $T = [(0.6 - 0.202)(2284 \text{ lbs-ft}) - (474 \text{ lbs-ft})] / (69.84 \text{ in}) / 1 \text{ anchors}$
 $T = 0 \text{ lbs/anchor, No Uplift}$

Wind

Anchors Resisting Shear = 4 anchors
 $V = (213 \text{ lbs}) / (4 \text{ anchors})$
 $V = 53 \text{ lbs/anchor}$
 Anchors Resisting Overturning Tension = 1 anchors
 Overturning Arm = 69.84 in
 $T = [0.6(1554 \text{ lbs-ft}) - (534 \text{ lbs-ft})] / (69.84 \text{ in}) / (1 \text{ anchors}) - (287 \text{ lbs}) / 2(1 \text{ anchors})$
 $T = 0 \text{ lbs/anchor, No Uplift}$



Summary

Max T = 21 lbs/anchor
 Max V = 157 lbs/anchor
 See page 14 for anchorage design.

City of Puyallup
 Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic

PRMH20221213





9600 SW Oak St #400
 Portland, OR 97223
 503.246.1250
 miller-se.com

Project Name South Hill Mall Mechanical Unit Replacement Project # 211478
 Location 3500 S Meridian Street, Puyallup, WA
 Client Coolsys Commercial & IND Solutions
 By ADJ Ck'd PRA Date 11/12/2021 Page 17 of 18

Fastener Check: (for unit to curb and curb to wood framing)

(ASD)



Bending in clip due to uplift

Tension =	21	lbs
Shear =	167	lbs
Clip Offset, Z =	2.5	in
Mreq =	54	lbs-in (assuming fixity at ea. end)
Clip Length =	8	in
Clip Gage =	16	No.
Clip Thickness =	0.0566	in
Plastic Section Modulus	0.00641	in ³
Clip Yield Strength =	50	ksi
Mallow =	192	lbs-in

OK

Clip Gauge:	16	= 0.0566	in
Adapter Curb Gauge:	18	= 0.0451	in

Screws ea. Leg of clip

n =	3	screws/leg
Clip Leg Length, X =	1.5	in
Tpry =	24	lbs/screw
Shear load per screw =	56	lbs/screw
T _{CAP} =	124	lbs/screw
V _{CAP} =	280	lbs/screw
Interaction =	0.39	

OK

Screw Type:	Generic Fasteners		
Screw Size:	#12		

Use 16 ga. Clips w/ (3) #12 self tapping screws ea. leg of bent clip

16 GA. Micrometl clip

Curb to Structure Anchorage

Use TEKS 3 HWH CL 1/4-14 X 1-1/2" Self-Drilling screws from curb into metal decking.

$T_{cap} = 880 \text{ lbs/FS} = 4.0 = 220 \text{ lbs} > 89 \text{ lbs}$ OK
 $V_{cap} = 2100 \text{ lbs/FS} = 2.5 = 840 \text{ lbs} > 214 \text{ lbs}$ OK

City of Puyallup
 Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic

PRMH20221213



9600 SW Oak St #400
Portland, OR 97223

503.246.1250
miller-se.com


Project Name South Hill Mall Mechanical Unit Replacement Project # 211478

Location 3500 S Meridian Street, Puyallup, WA

Client Coolsys Commercial & IND Solutions

By ADJ Ck'd PRA Date 11/12/2021 Page 18 of 18

Selector Guide



Part Number	Description	Head Style	Drill Point	Drill & Tap Capacity	Max. Material Attachment	Box Qty	Applications
1134000	12-14 x 3/4"	HWH	#3	.036-.210	.270	5,000	<ul style="list-style-type: none"> • Roof deck to steel framing • Wall panel to girt • Duct work to steel framing • Accessories to steel framing • Clip to steel framing • Retrofit framing
1136000	12-14 x 1"	HWH	#3	.036-.210	.520	4,000	
1120000	12-14 x 1-1/4"	HWH	#2	.036-.210	.550	4,000	
1123000	12-14 x 1-1/2"	HWH	#2	.036-.210	.800	2,500	
1140000	12-14 x 2"	HWH	#3	.036-.210	1.450	2,000	
1553000	12-14 X 2-1/2"	HWH	#3	.036-.210	1.950	1,000	
1143000	12-14 x 3"	HWH	#3	.036-.210	2.450	1,000	
1146000	12-14 x 4"	HWH	#3	.036-.210	3.450	500	
1147000	1/4-14 x 3/4"	HWH	#3	.036-.210	.210	3,000	
1149000	1/4-14 x 1"	HWH	#3	.036-.210	.400	2,500	
1150000	1/4-14 x 1-1/4"	HWH	#3	.036-.210	.650	2,000	
1152000	1/4-14 x 1-1/2"	HWH	#3	.036-.210	.900	2,000	
1155000	1/4-14 x 2"	HWH	#3	.036-.210	1.400	1,500	
1554000	1/4-14 x 2-1/2"	HWH	#3	.036-.210	1.900	1,000	
1157000	1/4-14 x 3"	HWH	#3	.036-.210	2.400	1,000	
1304000	1/4-14 x 4"	HWH	#3	.036-.210	3.400	500	
1587000	1/4-14 x 1"	*HWH	#3	.036-.210	.500	2,500	<ul style="list-style-type: none"> • Commercial overhead steel doors, hinges & latches.

* 7/16" Across Flats HWH with serrations under head.

Performance Data

PULLOUT VALUES (average lbs. ultimate)										
Fastener		Steel Gauge								
Dia.	Pt.	26	24	22	20	18	16	14	12	3/16
12	2	156	243	283	375	605	848	1181	1856	3520
	3	142	211	289	341	551	757	1063	1631	2998
1/4	3	141	231	293	346	613	880	1145	1858	4550

SHEAR VALUES (average lbs. ultimate)										
Fastener		Steel Gauge (lapped)								
Dia.	Pt.	26	24	22	20	18	16	14	12	
12	2	365	600	623	898	1370	1758	2138	2202	
	3	-	-	-	769	1358	1620	1970	1986	
1/4	3	-	-	-	930	1442	2100	2584	2650	

FASTENER VALUES			
Fastener (dia-tpi)	Tensile (lbs. min.)	Shear (avg. lbs. ult.)	Torque (min. in. lbs.)
12-14	2778	2000	92
1/4-14	4060	2600	150


SHEET STEEL GAUGES									
Gauge No.	26	24	22	20	18	16	14	12	
Decimal Equivalent	.018"	.024"	.030"	.036"	.048"	.060"	.075"	.105"	

The values listed are ultimate averages achieved under laboratory conditions and apply to Buildex manufactured fasteners only. Appropriate safety factors should be applied to these values for design purposes.

Installation Guidelines

- A standard screwgun with a depth sensitive nosepiece should be used to install TekS. For optimal fastener performance, the screwgun should be a minimum of 6 amps and have an RPM range of 0-2500.
- Adjust the screwgun nosepiece to properly seat the fastener.
- New magnetic sockets must be correctly set before use. Remove chip build-up as needed.

- The fastener is fully seated when the head is flush with the work surface.
- Overdriving may result in torsional failure of the fastener or stripout of the substrate.
- The fastener must penetrate beyond the metal structure a minimum of 3 pitches of thread.




700 High Grove Blvd
 Glendale Heights, Illinois 60139
 800-848-5611 Fax: 630-595-3549
 www.itwbuildex.com

PRMH20221213



Acoustics								
Sound Path	63 Hz	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
Ducted Discharge	84 dB	76 dB	69 dB	67 dB	61 dB	57 dB	57 dB	50 dB
Ducted Inlet	81 dB	74 dB	64 dB	58 dB	54 dB	48 dB	46 dB	40 dB
Outdoor Noise	84 dB	85 dB	80 dB	80 dB	77 dB	74 dB	70 dB	64 dB



PRMH20221213

Model Number Description - 3-10 Ton R-410A

Digit 1 - Unit Type

W Packaged Heat Pump³

Digit 2 - Efficiency

S Standard Efficiency

Digit 3 - Airflow

C Convertible

Digit 4,5,6 - Nominal Gross Cooling Capacity (MBh)

036 3 Tons
 048 4 Tons
 060 5 Tons
 072 6 Ton
 090 7½ Ton, Single Compressor
 120 10 Ton

Digit 7 - Major Design Sequence

E R-410A Refrigerant

Digit 8 - Voltage Selection

1 208/230/60/1
 3 208-230/60/3
 4 460/60/3
 W 575/60/3

Digit 9 - Unit Controls

R ReliaTel™ Microprocessor

Digit 10 - Heating Capacity

O=No Electric Heat F=14 kW (1 phase)¹
 A=5 kW (1 phase)¹ G=18 kW (1&3 phase)
 B=6 kW (3 phase) J=23 kW (3 phase)
 C=9 kW (3 phase) K= 27 kW (3 phase)
 D=10 kW (1 phase)¹ N = 36 kW (3 phase)
 E=12 kW (3 phase) P = 54 kW (3 phase)

Digit 11 - Minor Design Sequence

A First Sequence

Digit 12,13 - Service Sequence

** Factory Assigned

Digit 14 - Fresh Air Selection

0 No Fresh Air
 A Manual Outside Air Damper 0-50%²
 B Motorized Outside Air Damper 0-50%
 C Economizer, Dry Bulb 0-100% without Barometric Relief⁵
 D Economizer, Dry Bulb 0-100% with Barometric Relief⁵
 E Economizer, Reference Enthalpy 0-100% without Barometric Relief⁵
 F Economizer, Reference Enthalpy 0-100% with Barometric Relief⁵
 G Economizer, Comparative Enthalpy 0-100% without Barometric Relief⁵
 H Economizer, Comparative Enthalpy 0-100% with Barometric Relief⁵

Digit 15 - Supply Fan/Drive Type/Motor

0 Standard Drive⁴
 1 Oversized Motor
 2 Optional Belt Drive Motor

Digit 16 - Hinged Service Access/ Filters

0 Standard Panels/Standard Filters
 A Hinged Access Panels/Standard Filters
 B Standard Panels/2" MERV 7 Filters
 C Hinged Access Panels/2" MERV 7 Filters
 D Standard Panels/2" MERV 13 Filters
 E Hinged Access Panels/2" MERV 13 Filters

Digit 17 - Condenser Coil Protection

0 Standard Coil
 1 Standard Coil with Hail Guard
 2 Black Epoxy Pre-Coated Condenser Coil
 3 Black Epoxy Pre-Coated Condenser Coil with Hail Guard
 4 CompleteCoat™ Condenser Coil
 5 CompleteCoat™ Condenser Coil with Hail Guard

Digit 18 - Through the Base Provisions

0 No Through the Base Provisions
 A Through the Base Electric⁶

Digit 19 - Disconnect/Circuit Breaker (three-phase only)

0 No Disconnect/No Circuit Breaker
 1 Unit Mounted Non-Fused Disconnect⁶
 2 Unit Mounted Circuit Breaker⁶

Digit 20 - Convenience Outlet

0 No Convenience Outlet
 A Unpowered Convenience Outlet
 B Powered Convenience Outlet (three-phase only)⁷

Digit 21 - Communications Options

0 No Communications Interface

Digit 22 - Refrigeration System Option

0 Standard Refrigeration System⁸

Digit 23 - Refrigeration Controls


0 No Refrigeration Control³
 1 Frostat
 2 Crankcase Heater¹¹
 3 Frostat and Crankcase Heater¹¹

Digit 24 - Smoke Detector

0 No Smoke Detector
 A Return Air Smoke Detector⁹
 B Supply Air Smoke Detector
 C Supply and Return Air Smoke Detectors⁹

Digit 25 - Monitoring Controls

0 No Monitoring Control
 1 Clogged Filter Switch
 2 Fan Failure Switch
 3 Discharge Air Sensing Tube
 4 Clogged Filter Switch and Fan Fail Switch
 5 Clogged Filter Switch and Discharge Air Sensing Tube
 6 Fan Fail Switch and Discharge Air Sensing Tube
 7 Clogged Filter and Fan Fail Switches and Discharge Air Sensing Tube




Weights

WSC036E
564LBS WITH STATED ACC

Table 53. Maximum unit & corner weights (lbs) and center of gravity dimensions (in.)

Tons	Unit Model No.	Maximum Model Weights ^(a)		Corner Weights ^(b)				Center of Gravity (in.)	
		Shipping	Net	A	B	C	D	Length	Width
3	WSC036E	589	514	177	107	113	117	29	20
4	WSC048E	600	525	181	109	115	119	29	20
5	WSC060E	825	682	228	177	114	163	38	24
6	WSC072E	835	740	235	196	140	168	40	22
7½	WSC090E	902	804	255	217	153	180	41	22
10	WSC120E	1388	1199	342	328	259	270	49	28

(a) Weights are approximate.
 (b) Corner weights are given for information only.



City of Puyallup
 Development & Permitting Services
ISSUED PERMIT


Building	Planning
Engineering	Public Works
Fire	Traffic

Weights

Table 54. Factory installed options (fiops)/accessory net weights (lbs)(a),(b)

Accessory	WSC036E-048E	WSC***E	WSC072E-090E	WSC120E
	Net Weight	Net Weight	Net Weight	Net Weight
	3-4 Tons	5 Tons	6-7½ Tons	10 Tons
460 V IDM Transformer ^(c)	29	29	—	—
Barometric Relief	7	10	10	10
Belt Drive Option (3 phase only)	31	31	—	—
Coil Guards	12	20	20	30
Economizer	26	36	36	36
Electric Heaters ^(d)	15	30	30	40
Hinged Doors	10	12	12	12
Manual Outside Air Damper	16	26	26	26
Motorized Outside Air Damper	20	30	30	30
Oversized Motor	5	8	8	—
Powered Convenience Outlet	38	38	38	50
Powered Exhaust	—	80	80	80
Roof Curb	61	78	78	89
Smoke Detector, Supply	5	5	5	5
Smoke Detector, Return	7	7	7	7
Through the Base Electrical	8	13	8	13
Unit Mounted Circuit Breaker	5	5	5	5
Unit Mounted Disconnect	5	5	5	5


(a) Weights for options not listed are <5 lbs.
 (b) Net weight should be added to unit weight when ordering factory-installed accessories.
 (c) Apply weight with all 460V units with the Standard Direct Drive Motor.
 (d) Applicable to Heat Pump units only.





Acoustics

Sound Path	63 Hz	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
Ducted Discharge	84 dB	76 dB	69 dB	67 dB	61 dB	57 dB	57 dB	50 dB
Ducted Inlet	81 dB	74 dB	64 dB	58 dB	54 dB	48 dB	46 dB	40 dB
Outdoor Noise	84 dB	85 dB	80 dB	80 dB	77 dB	74 dB	70 dB	64 dB



PRMH20221213

Model Number Description - 3-10 Ton R-410A

Digit 1 - Unit Type

W Packaged Heat Pump³

Digit 2 - Efficiency

S Standard Efficiency

Digit 3 - Airflow

C Convertible

Digit 4,5,6 - Nominal Gross Cooling Capacity (MBh)

036 3 Tons
048 4 Tons
060 5 Tons
072 6 Ton
090 7½ Ton, Single Compressor
120 10 Ton

Digit 7 - Major Design Sequence

E R-410A Refrigerant

Digit 8 - Voltage Selection

1 208/230/60/1
3 208-230/60/3
4 460/60/3
W 575/60/3

Digit 9 - Unit Controls

R ReliaTel™ Microprocessor

Digit 10 - Heating Capacity

O=No Electric Heat F=14 kW (1 phase)¹
A=5 kW (1 phase)¹ G=18 kW (1&3 phase)
B=6 kW (3 phase) J=23 kW (3 phase)
C=9 kW (3 phase) K= 27 kW (3 phase)
D=10 kW (1 phase)¹ N = 36 kW (3 phase)
E=12 kW (3 phase) P = 54 kW (3 phase)

Digit 11 - Minor Design Sequence

A First Sequence

Digit 12,13 - Service Sequence

** Factory Assigned

Digit 14 - Fresh Air Selection

0 No Fresh Air
A Manual Outside Air Damper 0-50%²
B Motorized Outside Air Damper 0-50%
C Economizer, Dry Bulb 0-100% without Barometric Relief⁵
D Economizer, Dry Bulb 0-100% with Barometric Relief⁵
E Economizer, Reference Enthalpy 0-100% without Barometric Relief⁵
F Economizer, Reference Enthalpy 0-100% with Barometric Relief⁵
G Economizer, Comparative Enthalpy 0-100% without Barometric Relief⁵
H Economizer, Comparative Enthalpy 0-100% with Barometric Relief⁵

Digit 15 - Supply Fan/Drive Type/Motor

0 Standard Drive⁴
1 Oversized Motor
2 Optional Belt Drive Motor

Digit 16 - Hinged Service Access/ Filters

0 Standard Panels/Standard Filters
A Hinged Access Panels/Standard Filters
B Standard Panels/2" MERV 7 Filters
C Hinged Access Panels/2" MERV 7 Filters
D Standard Panels/2" MERV 13 Filters
E Hinged Access Panels/2" MERV 13 Filters

Digit 17 - Condenser Coil Protection

0 Standard Coil
1 Standard Coil with Hail Guard
2 Black Epoxy Pre-Coated Condenser Coil
3 Black Epoxy Pre-Coated Condenser Coil with Hail Guard
4 CompleteCoat™ Condenser Coil
5 CompleteCoat™ Condenser Coil with Hail Guard

Digit 18 - Through the Base Provisions

0 No Through the Base Provisions
A Through the Base Electric⁶

Digit 19 - Disconnect/Circuit Breaker (three-phase only)

0 No Disconnect/No Circuit Breaker
1 Unit Mounted Non-Fused Disconnect⁶
2 Unit Mounted Circuit Breaker⁶

Digit 20 - Convenience Outlet

0 No Convenience Outlet
A Unpowered Convenience Outlet
B Powered Convenience Outlet (three-phase only)⁷

Digit 21 - Communications Options

0 No Communications Interface

Digit 22 - Refrigeration System Option

0 Standard Refrigeration System⁸

Digit 23 - Refrigeration Controls


0 No Refrigeration Control³
1 Frostat
2 Crankcase Heater¹¹
3 Frostat and Crankcase Heater¹¹

Digit 24 - Smoke Detector

0 No Smoke Detector
A Return Air Smoke Detector⁹
B Supply Air Smoke Detector
C Supply and Return Air Smoke Detectors⁹

Digit 25 - Monitoring Controls

0 No Monitoring Control
1 Clogged Filter Switch
2 Fan Failure Switch
3 Discharge Air Sensing Tube
4 Clogged Filter Switch and Fan Fail Switch
5 Clogged Filter Switch and Discharge Air Sensing Tube
6 Fan Fail Switch and Discharge Air Sensing Tube
7 Clogged Filter and Fan Fail Switches and Discharge Air Sensing Tube




Weights

WSC036E
564LBS WITH STATED ACC

Table 53. Maximum unit & corner weights (lbs) and center of gravity dimensions (in.)

Tons	Unit Model No.	Maximum Model Weights ^(a)		Corner Weights ^(b)				Center of Gravity (in.)	
		Shipping	Net	A	B	C	D	Length	Width
3	WSC036E	589	514	177	107	113	117	29	20
4	WSC048E	600	525	181	109	115	119	29	20
5	WSC060E	825	682	228	177	114	163	38	24
6	WSC072E	835	740	235	196	140	168	40	22
7½	WSC090E	902	804	255	217	153	180	41	22
10	WSC120E	1388	1199	342	328	259	270	49	28

(a) Weights are approximate.
(b) Corner weights are given for information only.



City of Puyallup
Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic

85

Weights

Table 54. Factory installed options (fiops)/accessory net weights (lbs)(a),(b)


Accessory	WSC036E-048E	WSC***E	WSC072E-090E	WSC120E
	Net Weight	Net Weight	Net Weight	Net Weight
	3-4 Tons	5 Tons	6-7½ Tons	10 Tons
460 V IDM Transformer ^(c)	29	29	—	—
Barometric Relief	7	10	10	10
Belt Drive Option (3 phase only)	31	31	—	—
Coil Guards	12	20	20	30
Economizer	26	36	36	36
Electric Heaters ^(d)	15	30	30	40
Hinged Doors	10	12	12	12
Manual Outside Air Damper	16	26	26	26
Motorized Outside Air Damper	20	30	30	30
Oversized Motor	5	8	8	—
Powered Convenience Outlet	38	38	38	50
Powered Exhaust	—	80	80	80
Roof Curb	61	78	78	89
Smoke Detector, Supply	5	5	5	5
Smoke Detector, Return	7	7	7	7
Through the Base Electrical	8	13	8	13
Unit Mounted Circuit Breaker	5	5	5	5
Unit Mounted Disconnect	5	5	5	5

(a) Weights for options not listed are <5 lbs.

(b) Net weight should be added to unit weight when ordering factory-installed accessories.

(c) Apply weight with all 460V units with the Standard Direct Drive Motor.

(d) Applicable to Heat Pump units only.



PRMH20221213



Weights

Table 53. Maximum unit & corner weights (lbs) and center of gravity dimensions (in.)

Tons	Unit Model No.	Maximum Model Weights ^(a)		Corner Weights ^(b)				Center of Gravity (in.)	
		Shipping	Net	A	B	C	D	Length	Width
3	WSC036E	589	514	177	107	113	117	29	20
4	WSC048E	600	525	181	109	115	119	29	20
5	WSC060E	825	682	228	177	114	163	38	24
6	WSC072E	835	740	235	196	140	168	40	22
7½	WSC090E	902	804	255	217	153	180	41	22
10	WSC120E	1388	1199	342	328	259	270	49	28

(a) Weights are approximate.

(b) Corner weights are given for information only.



Weights

Table 54. Factory installed options (fiops)/accessory net weights (lbs)(a),(b)

Accessory	WSC036E-048E	WSC***E	WSC072E-090E	WSC120E
	Net Weight	Net Weight	Net Weight	Net Weight
	3-4 Tons	5 Tons	6-7½ Tons	10 Tons
460 V IDM Transformer ^(c)	29	29	—	—
Barometric Relief	7	10	10	10
Belt Drive Option (3 phase only)	31	31	—	—
Coil Guards	12	20	20	30
Economizer	26	36	36	36
Electric Heaters ^(d)	15	30	30	40
Hinged Doors	10	12	12	12
Manual Outside Air Damper	16	26	26	26
Motorized Outside Air Damper	20	30	30	30
Oversized Motor	5	8	8	—
Powered Convenience Outlet	38	38	38	50
Powered Exhaust	—	80	80	80
Roof Curb	61	78	78	89
Smoke Detector, Supply	5	5	5	5
Smoke Detector, Return	7	7	7	7
Through the Base Electrical	8	13	8	13
Unit Mounted Circuit Breaker	5	5	5	5
Unit Mounted Disconnect	5	5	5	5

(a) Weights for options not listed are <5 lbs.

(b) Net weight should be added to unit weight when ordering factory-installed accessories.

(c) Apply weight with all 460V units with the Standard Direct Drive Motor.

(d) Applicable to Heat Pump units only.

