

### City of Puyallup

#### **Building Division**

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

### INSPECTION REPORT

Date of Inspection: Aug 29, 2022 Inspection Result: PARTIAL PASS

Permit Number: B-21-0544

**Property Address:** 4423 S MERIDIAN;

Contractor: PROBUILD CONSTRUCTION 12112 92ND AVE CT E PUYALLUP, WA

98373

**To construct**: TI ~ TANDOORI GRILLBLDG/PLUMB/MECH STE # 715

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

## Comments:

#### Corrections:

- 1 1. Paint gas pipe exterior of building
  - 2. Provide drip leg at gas line at hot water tank
  - 3. Provide 1 inch clearance at the vent to combustibles
  - 4. Provide support of expansion tank at hot water tank
  - 5. Provide hammer arrestor at dishwasher
  - 6. Support be vent for hot water tank
  - 7. Paint grease trap vent next to rear door outside
  - 8. Provide city approved plans for next inspection
  - 9. Not a complete list
  - 10. Not ready
- 2 1.complete all grab bars
  - 2.provide 1" clearance to b-vent at ceiling tile
  - 3. remove thumb turn at main egress/ingress door
  - 4. ok to due take out and door dash orders only

Sincerely,



# City of Puyallup

# **Building Division**

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684