



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 30, 2022

Inspection Result: **FAILED**

Permit Number: B-21-0029

Property Address: 2505 INTER AVE ;

Contractor:

To construct: CHANGE OF USE FROM R3 TO OFFICE USE ~ PRO VAC

BLDG/PLUMB/MECH 2015 CODES

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. provide plumbing boot at supplies in both bath rooms
2. complete all handrails at 34" to 38" above stair nosing as discussed with contractor
3. clean all debris from crawl space
4. provide proper vapor barrier
5. Provide bearing at beams in crawlspace per conversation with contractor
6. Provide ADA signage
7. complete insulation at main trunk line of supply line crawl space
8. use treated wood at all screen at foundation vents
9. provide insulation at cans in attic space
10. provide insulation at crawl space lid
11. provide clearance from ground to main trunk line in crawlspace

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684