



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 31, 2022

Inspection Result: **FAILED**

Permit Number: PRPF20220743

Property Address: 1501 39TH AVE SW, PUYALLUP, WA 98373;

Contractor: ARIES BUILDING SYSTEMS LLC 4211 FACTORIA BLVD ST SE BELLEVUE,
WA 98006 (425) 644-3571

To construct: Relocate one (1) existing dry portable to Kessler.

On this day we have inspected your construction for **Engineering Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 Downspouts on southside of building do not provide for flow away from the building.

Sincerely,

Michael Rosenau
Engineering Tech IV
MRosenau@PuyallupWA.gov
(253) 841-5411