



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 31, 2022

Inspection Result: PASSED

Permit Number: B-21-0544

Property Address: 4423 S MERIDIAN;

Contractor: PROBUILD CONSTRUCTION 12112 92ND AVE CT E PUYALLUP, WA 98373

To construct: TI ~ TANDOORI GRILLBLDG/PLUMB/MECH STE # 715

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. Paint gas pipe exterior of building
2. Provide drip leg at gas line at hot water tank
3. Provide 1 inch clearance at the vent to combustibles
4. Provide support of expansion tank at hot water tank
5. Provide hammer arrestor at dishwasher
6. Support be vent for hot water tank
7. Paint grease trap vent next to rear door outside
8. Provide city approved plans for next inspection
9. Not a complete list
10. Not ready
- 2 1.complete all grab bars
- 2.provide 1" clearance to b-vent at ceiling tile
3. remove thumb turn at main egress/ingress door
4. ok to due take out and door dash orders only

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive style.

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684