



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 08, 2022 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20220873

Property Address: 2504 E MAIN, PUYALLUP, WA 98372;

Contractor: POE CONSTRUCTION INC PO BOX 899 AUBURN, WA 98071-0899

To construct: Expansion of existing conditioned office and mezzanine TI in existing warehouse building, including new elevator. New break room, restrooms and offices in warehouse area. Incorporation of light manufacturing equipment and processes within warehouse. Envelope upgrades for full conditioning of warehouse space per deferred HVAC Design/Build submittal. Repurposing of existing on-site trailer parking area with auto parking stalls to support new manufacturing use.

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; approved footings approved except foundation walls of elevator.

Corrections:

- 1 1. Provide city approved plans on site at time of next inspection
2. not ready
- 2 concrete progressing with special insp, received ctl report.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684