LIGHTING COMPLIANCE SUMMARY

2018 WSEC Compliance Forms for Commercial Buildings including Group R2, R3 & R4 over 3 stories and all R1

Administered by: ©2022 NEEA, All rights reserved

		Project Title	MULTICARE GSMOB ORTHOPEDICS & SPORTS MEDICINE CLINIC T.I - 2018 WSEC	For Building Department Use:	Date:	Aug 09, 2022
P	roject & Applicant	Project Address	1450 5TH ST SE PYALLUP, WA 98372		Date.	11ug 05, 2022
	formation	Applicant Name	Coffman Engineers			
		Applicant Phone	206-623-0717			
		Applicant Email	SeattleNREC@coffman.com			
	I	or questions about this	report, contact WSEC Commercial Technical Support at 360-539-5300 or via email at com.techsupport	ort@waenergycodes.com	•	

General Occupancy	All	Commercial	General Building Use Type		Healthcare, Hospital	Building Cond. Floor Area	1,493
• •		New Building or	3 11			Project Cond. Floor Area	1,493
General Project Types		Addition		Alteration Lighting Scope	Interior Lighting	Floors Above Grade	4
		Lighting Scope		Eighting Scope		Compliance Method	Compliance Method 1 - General
Lighting Project Description				NEW I	LED FIXTURES		

Lighting Compliance Scope and Method	Project Type	Interior / Exterior (Interior includes both interior & parking)	Luminaire Replacement Scope	Compliance Method	LPA Calculation Adjustment	Compliance Verification
and Method	Alteration	Interior Lighting	50% or more replaced	Building area	No Calculation Adjustments allowed	COMPLIES
Additional Efficiency Options Included	Redu	uced lighting power density credit				

Project Title	MULTICARE GS	SMOB ORTHOP	EDICS & SPORTS MEDICINE CLIN	IC T.I - 2018 WSEC		Date	Aug	09, 2022
Lighting Power Calc	culation	ALTERATION	- INTERIOR LIGHTING (50% or mo	re replaced)	Co	ompliance Verific	ation	COMPLIES
Compliance Method			Building area	LPA Calculation Adjustment				none

		Interior Lighting	Power Allowance - Building Area		
Building Areas	Gross Interior Area (SF)	LPA (Watts/SF)	Total Watts Allowed (SF x LPA x 1)	Total Proposed Watts By Building Area	Compliance Status by Building Area
Hospital	1,493	0.84	1,254	1,151	COMPLIES

]	Proposed Lighting Power Density				
Fixture Type/Application	Fixture ID	Building Area	New or Existing-to-Remain	Quantity of Fixtures, CLDs or Luminaires (#F)	Watts per Fixture, CLD or Luminaire (WpF)	Total Linear Feet (LF)	Watts per Linear Foot (WpLF)	Total Watts Proposed (#F x WpF) or (LF x WpLF)
Individual Fixtures								
Recessed downlight	RB1E	Hospital	New	5	44			220
Recessed downlight	RA1	Hospital	New	20	38			760
Recessed downlight	RB1	Hospital	New	3	44			132
Wall-mounted	WA1	Hospital	New	1	21			21
Other fixture type	DA1	Hospital	New	1	18			18

Project Title N	MULTICAR	E GSMOB ORTHO	PEDICS & SPORTS MEDICINE CLINIC T.I - 2	018 WSEC		Date	Aug 09, 2022
Proposed Fixtures Det	tails	ALTERATION	N - INTERIOR LIGHTING (50% or more replace	ed)			
Fixture Type/Applicat	tion	Fixture ID	Location in Documents	Lamp Type	Building Area		New or Existing-to-Remain
Individual Fixtures							
Recessed o	downlight	RB1E	E2.1	LED	Hospital		New

	Fixture Description: 2X2 REC	ESS MOUNT GASKETED LED LUMINAIRE WITH EM		Are these fixtures located within a c	laylight zone?: No
	Do these fixtures require speci	fic application lighting controls?: None required			
Recessed downlight	RA1	E2.1	LED	Hospital	New
	Fixture Description: 2X4 REC	ESS MOUNT GASKETED LED LUMINAIRE		Are these fixtures located within a c	laylight zone?: No
	Do these fixtures require speci	fic application lighting controls?: None required			
Recessed downlight	RB1	E2.1	LED	Hospital	New
	Fixture Description: 2X2 REC	ESS MOUNT GASKETED LED LUMINAIRE	Are these fixtures located within a daylight zone?: No		
	Do these fixtures require speci	fic application lighting controls?: None required			
Wall-mounted	WA1	E2.1	LED	Hospital	New
	Fixture Description: WALL M	OUNT LINEAR LED VANITY LUMINAIRE		Are these fixtures located within a c	laylight zone?: No
	Do these fixtures require speci	fic application lighting controls?: None required			
Other fixture type	DA1	E2.1	LED	Hospital	New
	Fixture Description: RECESS	MOUNT LED DOWNLIGHT LUMINAIRE	Are these fixtures located within a c	laylight zone?: No	
	Do these fixtures require speci	fic application lighting controls?: None required			