



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 15, 2022 **Inspection Result:** **PARTIAL PASS**

Permit Number: E-21-0440

Property Address: 3303 8TH AVE SE ;

Contractor: MOUNTAIN CONSTRUCTION INC. 7457 S MADISON TACOMA, WA
98409 Jeremy Patnoi 7457 S. Madison St. Tacoma, WA 98409

To construct: SEWER MODIFICATION AT THE EXISTING STEP BY STEP FACILITY ~ STEP
BY STEP

confirm fees pls

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: All storm structures have been completed.

Corrections:

1 Punch List "A"

1. ALL sewer c/o covers need to be installed.
2. Sewer pump riser needs to be sealed.
3. Need ALL disturbed areas stabilized.
4. Need fire line RPBA cert.
5. Need fire line final, tamper switches tested and passed by fire inspector.

Punch List "B"

1. ALL existing septic drain field needs to be decommissioned.
2. Need storm, sewer, and water as-builts.
3. Need storm water maintenance agreement.
4. Finish all concrete when pedestrian re-routes are accessible.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by a series of vertical, wavy lines that resemble a stylized 'L' or a series of connected loops. A horizontal line extends to the right from the middle of the signature.

Jason Little
Engineering Tech IV
JLittle@PuyallupWA.gov
(253) 435-3636